



**Dream Pools And Spas  
1105 Washington Blvd  
Pittsburgh, Pennsylvania 15206  
(412) 661-7665  
Laboratory Analysis Report**

Lab ID No. 02-04041  
**APM 1**

**Lab# 2057**

**Customer** American Pools Management  
3261 Babcock Blvd.  
Pittsburgh, PA 15237

Facility Name: Brentwood Borough Pool

**Sample Collection**

Date: 8/12/25

Time: 1:50 PM

Method: Grab

Address: Park Dr.  
Pittsburgh, PA 15227

**Sample Final Analysis**

Date: 8/15/25

Time: 9:00 AM

Analyst: AS

Matrix: Recreational Water

Source Type: Shallow End

Accredited Analysis	Results	Reporting limit	Incubation Date/Time	Analyst	Method
Escherichia Coli:	Absent	Absent	8/13/25	11:00 AM	EB
Total coliforms:	0/100mls	2/100mls	8/13/25	11:00 AM	EB
Standard plate count:	0/ml	200/ml	8/12/25	5:00 PM	SL

Field Analysis	Results	Reporting limit	Date/Time	Analyst	Method
pH:	8.0 SU	7.2 - 7.8 SU	8/12/25	1:50 PM	BL
Chlorine:	10.0 mg/l	1.0 - 5.0 mg/l	8/12/25	1:50 PM	BL
Turbidity:	1 NTU	1 - 2 NTU	8/12/25	1:50 PM	BL

**Sample comments**

A handwritten signature in black ink that reads "Andre Smith".

(When exceeding reporting limit pool or spa is unfit)

---

Andre Smith, Lead Supervisor



**Dream Pools And Spas  
1105 Washington Blvd  
Pittsburgh, Pennsylvania 15206  
(412) 661-7665  
Laboratory Analysis Report**

Lab ID No. 02-04041  
**APM 1**

**Lab# 2057**

**Customer** American Pools Management  
3261 Babcock Blvd.  
Pittsburgh, PA 15237

Facility Name: Brentwood Borough Pool

**Sample Collection**

Date: 8/12/25

Time: 1:50 PM

Method: Grab

Address: Park Dr.  
Pittsburgh, PA 15227

**Sample Final Analysis**

Date: 8/15/25

Time: 9:00 AM

Analyst: AS

Matrix: Recreational Water

Source Type: Shallow End

Accredited Analysis	Results	Reporting limit	Incubation Date/Time	Analyst	Method
Escherichia Coli:	Absent	Absent	8/13/25	11:00 AM	EB
Total coliforms:	0/100mls	2/100mls	8/13/25	11:00 AM	EB
Standard plate count:	0/ml	200/ml	8/12/25	5:00 PM	SL

Field Analysis	Results	Reporting limit	Date/Time	Analyst	Method
pH:	8.0 SU	7.2 - 7.8 SU	8/12/25	1:50 PM	BL
Chlorine:	10.0 mg/l	1.0 - 5.0 mg/l	8/12/25	1:50 PM	BL
Turbidity:	1 NTU	1 - 2 NTU	8/12/25	1:50 PM	BL

**Sample comments**

A handwritten signature in black ink that reads "Andre Smith".

(When exceeding reporting limit pool or spa is unfit)

---

Andre Smith, Lead Supervisor