Dream Pools and Spas
1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661- 7665
Laboratory Analysis Report

Lab ID No. 02-04041

C-10

Lab# 2401

Customer

		Sample Collection	
Facility Name:	*Pgh Golf Club*	*Date:*	*8/11/25*
		Time:	9:55 AM
Address:	*5280 Northumberland St.*	*Method:*	*Grab*
	Pittsburgh, PA 15217		
		Sample Final Analysis	
Matrix:	*Recreational Water*	*Date:*	*8/14/25*
		Time:	*9:00 AM*
Source Type:	*Pool - Deep*	*Analyst:*	*AS*

Accredited Analysis	Results	Reporting limit	Incubation Date/Time		Analyst	Method
Escherichia Coli:	Absent	Absent	8/12/25	9:00 AM	EB	SM 9222G
Total coliforms:	0/100mls	2/100mls	8/12/25	9:00 AM	EB	SM 9222B
Standard plate count:	0/ml	200/ml	8/11/25	2:31 PM	EB	SM 9215B

Field Analysis	Results	Reporting limit	Date/Time		Analyst	Method
pH:	7.6 SU	7.2 - 7.8 SU	8/11/25	9:55 AM	LM	DPD
Chlorine:	1.0 mg/l	1.0 - 5.0 mg/l	8/11/25	9:55 AM	LM	DPD
Turbidity:	1 NTU	1 - 2 NTU	8/11/25	9:55 AM	LM	Visual

Sample comments

(When exceeding reporting limit pool or spa is unfit)

Andre Smith

Andre Smith, Lead Supervisor

Dream Pools and Spas
1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661- 7665
Laboratory Analysis Report

Lab ID No. 02-04041

C-10

Lab# *2401*

Customer

Facility Name:	Pgh Golf Club
Address:	5280 Northumberland St. Pittsburgh, PA 15217
Matrix:	Recreational Water
Source Type:	Pool - Deep

Sample Collection

Date:	8/11/25
Time:	9:55 AM
Method:	Grab

Sample Final Analysis

Date:	8/14/25
Time:	9:00 AM
Analyst:	AS

Accredited Analysis	Results	Reporting limit	Incubation Date/Time		Analyst	Method
Escherichia Coli:	Absent	Absent	8/12/25	9:00 AM	EB	SM 9222G
Total coliforms:	0/100mls	2/100mls	8/12/25	9:00 AM	EB	SM 9222B
Standard plate count:	0/ml	200/ml	8/11/25	2:31 PM	EB	SM 9215B

Field Analysis	Results	Reporting limit	Date/Time		Analyst	Method
pH:	7.6 SU	7.2 - 7.8 SU	8/11/25	9:55 AM	LM	DPD
Chlorine:	1.0 mg/l	1.0 - 5.0 mg/l	8/11/25	9:55 AM	LM	DPD
Turbidity:	1 NTU	1 - 2 NTU	8/11/25	9:55 AM	LM	Visual

Sample comments

(When exceeding reporting limit pool or spa is unfit)

Andre Smith

Andre Smith, Lead Supervisor