



**Dream Pools and Spas  
1105 Washington Blvd  
Pittsburgh, Pennsylvania 15206  
(412) 661-7665  
Laboratory Analysis Report**

Lab ID No. 02-04041

S-3

Lab# 156

**Customer**

Facility Name: Holiday Inn  
Address: 3053 Washington Pike  
Bridgeville, PA 15017  
Matrix: Recreational Water  
Source Type: Pool

**Sample Collection**

Date: 9/15/25  
Time: 1:18 PM  
Method: Grab

**Sample Final Analysis**

Date: 9/18/25  
Time: 9:00 AM  
Analyst: AS

Accredited Analysis	Results	Reporting limit	Incubation Date/Time	Analyst	Method
Escherichia Coli:	Absent	Absent	9/16/25	9:00 AM	JC
Total coliforms:	0/100mls	2/100mls	9/16/25	9:00 AM	JC
Standard plate count:	0/ml	200/ml	9/15/25	3:30 PM	AS

Field Analysis	Results	Reporting limit	Date/Time	Analyst	Method
pH:	7.8 SU	7.2 - 7.8 SU	9/15/25	1:18 PM	GR
Chlorine:	5.0 mg/l	1.0 - 5.0 mg/l	9/15/25	1:18 PM	GR
Turbidity:	1 NTU	1 - 2 NTU	9/15/25	1:18 PM	GR

**Sample comments**

(When exceeding reporting limit pool or spa is unfit)

*Andre Smith*

Andre Smith, Lead Supervisor