

Dream Pools and Spas 1105 Washington Blvd Pittsburgh, Pennsylvania 15206 (412) 661- 7665 Laboratory Analysis Report

Lab ID No. 02-04041

SERVICE

Lab# 2299

<u>Customer</u> <u>Sample Collection</u>

Facility Name: Jefferson Estates Date: 5/28/25
Time: 1:30 PM

Address: Woodwind Dr. Method: Grab

Jefferson Hills, PA 15025

Matrix: Recreational Water Sample Final Analysis

Date: 5/31/25

Source Type: Pool Time: 9:30 AM Analyst: AS

Accredited Analysis	Results	Reporting limit	Incubation Date/Time		Analyst	Method
Escherichia Coli:	Absent	Absent	5/29/25	10:05 AM	EB	SM 9222G
Total coliforms:	0/100mls	2/100mls	5/29/25	10:05 AM	EB	SM 9222B
Standard plate count:	0/ml	200/ml	5/28/25	5:36 PM	АН	SM 9215B

Field Analysis	Results	Reporting limit	D	ate/Time	Analyst	Method
pH:	7.6 SU	7.2 - 7.8 SU	5/28/25	1:30 PM	DW	DPD
Chlorine:	3.0 mg/l	1.0 - 5.0 mg/l	5/28/25	1:30 PM	DW	DPD
Turbidity:	1 NTU	1 - 2 NTU	5/28/25	1:30 PM	DW	Visual

Sample comments

(When exceeding reporting limit pool or spa is unfit)

andre Smith

Andre Smith, Lead Supervisor



Dream Pools and Spas 1105 Washington Blvd Pittsburgh, Pennsylvania 15206 (412) 661- 7665 Laboratory Analysis Report

Lab ID No. 02-04041

SERVICE

Lab# 2299

<u>Customer</u> <u>Sample Collection</u>

Facility Name: Jefferson Estates Date: 5/28/25
Time: 1:30 PM

Address: Woodwind Dr. Method: Grab

Jefferson Hills, PA 15025

Matrix: Recreational Water Sample Final Analysis

Date: 5/31/25

Source Type: Pool Time: 9:30 AM Analyst: AS

Accredited Analysis	Results	Reporting limit	Incubation Date/Time		Analyst	Method
Escherichia Coli:	Absent	Absent	5/29/25	10:05 AM	EB	SM 9222G
Total coliforms:	0/100mls	2/100mls	5/29/25	10:05 AM	EB	SM 9222B
Standard plate count:	0/ml	200/ml	5/28/25	5:36 PM	АН	SM 9215B

Field Analysis	Results	Reporting limit	D	ate/Time	Analyst	Method
pH:	7.6 SU	7.2 - 7.8 SU	5/28/25	1:30 PM	DW	DPD
Chlorine:	3.0 mg/l	1.0 - 5.0 mg/l	5/28/25	1:30 PM	DW	DPD
Turbidity:	1 NTU	1 - 2 NTU	5/28/25	1:30 PM	DW	Visual

Sample comments

(When exceeding reporting limit pool or spa is unfit)

andre Smith

Andre Smith, Lead Supervisor