Dream Pools and Spas
1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661- 7665
Laboratory Analysis Report

Lab ID No. 02-04041

N-10

Lab# **2074**

Customer			*Sample Collection*	
Facility Name:	*Camp Guyasuta*		*Date:*	*6/10/25*
			Time:	9:50 AM
Address:	*300 23rd Street*		*Method:*	*Grab*
	Sharpsburg, PA 15215			
			Sample Final Analysis	
Matrix:	*Recreational Water*		*Date:*	*6/13/25*
			Time:	*9:30 AM*
Source Type:	*Shallow End*		*Analyst:*	*AS*

Accredited Analysis	Results	Reporting limit	Incubation Date/Time		Analyst	Method
Escherichia Coli:	Absent	Absent	6/11/25	10:30 AM	AH	SM 9222G
Total coliforms:	0/100mls	2/100mls	6/11/25	10:30 AM	AH	SM 9222B
Standard plate count:	0/ml	200/ml	6/10/25	4:33 PM	AH	SM 9215B

Field Analysis	Results	Reporting limit	Date/Time		Analyst	Method
pH:	8.0 SU	7.2 - 7.8 SU	6/10/25	9:50 AM	BH	DPD
Chlorine:	7.5 mg/l	1.0 - 5.0 mg/l	6/10/25	9:50 AM	BH	DPD
Turbidity:	1 NTU	1 - 2 NTU	6/10/25	9:50 AM	BH	Visual

Sample comments

(When exceeding reporting limit pool or spa is unfit)

Andre Smith

Andre Smith, Lead Supervisor

Dream Pools and Spas
1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661- 7665
Laboratory Analysis Report

Lab ID No. 02-04041

Lab# 2074

Customer

Facility Name:	*Camp Guyasuta*
Address:	*300 23rd Street*
	Sharpsburg, PA 15215
Matrix:	*Recreational Water*
Source Type:	*Shallow End*

Sample Collection

Date:	*6/10/25*
Time:	9:50 AM
Method:	*Grab*

Sample Final Analysis

Date:	*6/13/25*
Time:	*9:30 AM*
Analyst:	AS

Accredited Analysis	Results	Reporting limit	Incubation Date/Time		Analyst	Method
Escherichia Coli:	Absent	Absent	6/11/25	10:30 AM	AH	SM 9222G
Total coliforms:	0/100mls	2/100mls	6/11/25	10:30 AM	AH	SM 9222B
Standard plate count:	0/ml	200/ml	6/10/25	4:33 PM	AH	SM 9215B

Field Analysis	Results	Reporting limit	Date/Time		Analyst	Method
pH:	8.0 SU	7.2 - 7.8 SU	6/10/25	9:50 AM	BH	DPD
Chlorine:	7.5 mg/l	1.0 - 5.0 mg/l	6/10/25	9:50 AM	BH	DPD
Turbidity:	1 NTU	1 - 2 NTU	6/10/25	9:50 AM	BH	Visual

Sample comments

(When exceeding reporting limit pool or spa is unfit)

Andre Smith, Lead Supervisor