



**Dreams Pools and Spas**  
**1105 Washington Blvd**  
**Pittsburgh, Pennsylvania 15206**  
**(412) 661- 7665**  
**Laboratory Analysis Report**

Lab ID No. 02-04041

**PPS**

**Lab# 310**

**Customer**

Facility Name: University Prep Middle School

Address: 3117 Centre Ave.  
Pittsburgh, PA 15219

Matrix: Recreational Water

Source Type: Pool Shallow

**Sample Collection**

Date: 7/15/25

Time: 12:41 PM

Method: Grab

**Sample Final Analysis**

Date: 7/18/25

Time: 9:30 AM

Analyst: AS

Accredited Analysis	Results	Rating	Incubation	Date/Time	Analyst	Method
Escherichia Coli:	Absent	A	7/16/25	10:10 AM	EB	SM 9222G
Total coliforms:	0/100mls	A	7/16/25	10:10 AM	EB	SM 9222B
Standard plate count:	0/ml	A	7/15/25	4:00 PM	EB	SM 9215B

Field Analysis	Results	Rating	Date/Time	Analyst	Method	
pH:	7.6 SU	A	7/15/25	12:41 PM	SL	DPD
Chlorine:	3.0 mg/l	A	7/15/25	12:41 PM	SL	DPD
Turbidity:	1 NTU	A	7/15/25	12:41 PM	SL	Visual

**Sample comments**

*Andre Smith*

( When exceeding reporting limit pool or spa is unfit)

Andre Smith, Lead Supervisor



**Dreams Pools and Spas**  
**1105 Washington Blvd**  
**Pittsburgh, Pennsylvania 15206**  
**(412) 661- 7665**  
**Laboratory Analysis Report**

Lab ID No. 02-04041

**PPS**

**Lab# 310**

**Customer**

Facility Name: University Prep Middle School

Address: 3117 Centre Ave.  
Pittsburgh, PA 15219

Matrix: Recreational Water

Source Type: Pool Shallow

**Sample Collection**

Date: 7/15/25

Time: 12:41 PM

Method: Grab

**Sample Final Analysis**

Date: 7/18/25

Time: 9:30 AM

Analyst: AS

Accredited Analysis	Results	Rating	Incubation	Date/Time	Analyst	Method
Escherichia Coli:	Absent	A	7/16/25	10:10 AM	EB	SM 9222G
Total coliforms:	0/100mls	A	7/16/25	10:10 AM	EB	SM 9222B
Standard plate count:	0/ml	A	7/15/25	4:00 PM	EB	SM 9215B

Field Analysis	Results	Rating	Date/Time	Analyst	Method	
pH:	7.6 SU	A	7/15/25	12:41 PM	SL	DPD
Chlorine:	3.0 mg/l	A	7/15/25	12:41 PM	SL	DPD
Turbidity:	1 NTU	A	7/15/25	12:41 PM	SL	Visual

**Sample comments**

*Andre Smith*

( When exceeding reporting limit pool or spa is unfit)

Andre Smith, Lead Supervisor