



**Dream Pools and Spas**  
**1105 Washington Blvd**  
**Pittsburgh, Pennsylvania 15206**  
**(412) 661- 7665**  
**Laboratory Analysis Report**

Lab ID No. 02-04041  
**APM 4**

**Lab# 2544**

**Customer**

*American Pools Management*  
*3261 Babcock Blvd.*  
*Pittsburgh, PA 15237*

**Sample Collection**

*Facility Name: Valleybrook Swim Club*

*Date: 7/22/25*

*Address: 100 Callender Rd*  
*Pittsburgh, PA 15237*

*Time: 12:00 AM*

*Method: Grab*

**Sample Final Analysis**

*Matrix: Recreational Water*

*Date: 7/25/25*

*Source Type: Shallow End*

*Time: 10:00 AM*

*Analyst: AS*

Accredited Analysis	Results	Reporting limit	Incubation Date/Time		Analyst	Method
Escherichia Coli:	Absent	Absent	7/23/25	12:40 PM	SL	SM 9222G
Total coliforms:	0/100mls	2/100mls	7/23/25	12:40 PM	SL	SM 9222B
Standard plate count:	0/ml	200/ml	7/22/25	6:00 PM	SL	SM 9215B

Field Analysis	Results	Reporting limit	Date/Time		Analyst	Method
pH:	7.4 SU	7.2 - 7.8 SU	7/22/25	10:39 AM	MM	DPD
Chlorine:	3.0 mg/l	1.0 - 5.0 mg/l	7/22/25	10:39 AM	MM	DPD
Turbidity:	1 NTU	1 - 2 NTU	7/22/25	10:39 AM	MM	Visual

**Sample comments**

*Andre Smith*

( When exceeding reporting limit pool or spa is unfit)

Andre Smith, Lead Supervisor



**Dream Pools and Spas**  
**1105 Washington Blvd**  
**Pittsburgh, Pennsylvania 15206**  
**(412) 661- 7665**  
**Laboratory Analysis Report**

Lab ID No. 02-04041  
**APM 4**

**Lab# 2544**

**Customer**

*American Pools Management*  
*3261 Babcock Blvd.*  
*Pittsburgh, PA 15237*

**Sample Collection**

*Facility Name: Valleybrook Swim Club*

*Date: 7/22/25*

*Address: 100 Callender Rd*  
*Pittsburgh, PA 15237*

*Time: 12:00 AM*

*Method: Grab*

**Sample Final Analysis**

*Matrix: Recreational Water*

*Date: 7/25/25*

*Source Type: Shallow End*

*Time: 10:00 AM*

*Analyst: AS*

Accredited Analysis	Results	Reporting limit	Incubation Date/Time		Analyst	Method
Escherichia Coli:	Absent	Absent	7/23/25	12:40 PM	SL	SM 9222G
Total coliforms:	0/100mls	2/100mls	7/23/25	12:40 PM	SL	SM 9222B
Standard plate count:	0/ml	200/ml	7/22/25	6:00 PM	SL	SM 9215B

Field Analysis	Results	Reporting limit	Date/Time		Analyst	Method
pH:	7.4 SU	7.2 - 7.8 SU	7/22/25	10:39 AM	MM	DPD
Chlorine:	3.0 mg/l	1.0 - 5.0 mg/l	7/22/25	10:39 AM	MM	DPD
Turbidity:	1 NTU	1 - 2 NTU	7/22/25	10:39 AM	MM	Visual

**Sample comments**

*Andre Smith*

( When exceeding reporting limit pool or spa is unfit)

Andre Smith, Lead Supervisor