



**Dream Pools and Spas**  
**1105 Washington Blvd**  
**Pittsburgh, Pennsylvania 15206**  
**(412) 661- 7665**  
**Laboratory Analysis Report**

Lab ID No. 02-04041

**N-14**

**Lab# 2673**

**Customer**

Facility Name: Traditions of America

Address: 507 Rochester Rd.  
Cranberry, PA 16066

Matrix: Recreational Water

Source Type: Pool

**Sample Collection**

Date: 6/23/25

Time: 12:36 PM

Method: Grab

**Sample Final Analysis**

Date: 6/26/25

Time: 9:00 AM

Analyst: AS

Accredited Analysis	Results	Reporting limit	Incubation	Date/Time	Analyst	Method
Escherichia Coli:	Absent	Absent	6/24/25	10:00 AM	AH	SM 9222G
Total coliforms:	0/100mls	2/100mls	6/24/25	10:00 AM	AH	SM 9222B
Standard plate count:	0/ml	200/ml	6/23/25	3:24 PM	EB	SM 9215B

Field Analysis	Results	Reporting limit	Date/Time	Analyst	Method	
pH:	7.2 SU	7.2 - 7.8 SU	6/23/25	12:36 PM	ZR	DPD
Chlorine:	1.0 mg/l	1.0 - 5.0 mg/l	6/23/25	12:36 PM	ZR	DPD
Turbidity:	1 NTU	1 - 2 NTU	6/23/25	12:36 PM	ZR	Visual

**Sample comments**

Andre Smith, Lead Supervisor

( When exceeding reporting limit pool or spa is unfit)



**Dream Pools and Spas**  
**1105 Washington Blvd**  
**Pittsburgh, Pennsylvania 15206**  
**(412) 661- 7665**  
**Laboratory Analysis Report**

Lab ID No. 02-04041

**N-14**

**Lab# 2673**

**Customer**

Facility Name: Traditions of America

Address: 507 Rochester Rd.  
Cranberry, PA 16066

Matrix: Recreational Water

Source Type: Pool

**Sample Collection**

Date: 6/23/25

Time: 12:36 PM

Method: Grab

**Sample Final Analysis**

Date: 6/26/25

Time: 9:00 AM

Analyst: AS

Accredited Analysis	Results	Reporting limit	Incubation	Date/Time	Analyst	Method
Escherichia Coli:	Absent	Absent	6/24/25	10:00 AM	AH	SM 9222G
Total coliforms:	0/100mls	2/100mls	6/24/25	10:00 AM	AH	SM 9222B
Standard plate count:	0/ml	200/ml	6/23/25	3:24 PM	EB	SM 9215B

Field Analysis	Results	Reporting limit	Date/Time	Analyst	Method	
pH:	7.2 SU	7.2 - 7.8 SU	6/23/25	12:36 PM	ZR	DPD
Chlorine:	1.0 mg/l	1.0 - 5.0 mg/l	6/23/25	12:36 PM	ZR	DPD
Turbidity:	1 NTU	1 - 2 NTU	6/23/25	12:36 PM	ZR	Visual

**Sample comments**

Andre Smith, Lead Supervisor

( When exceeding reporting limit pool or spa is unfit)