

Dream Pools and Spas 1105 Washington Blvd Pittsburgh, Pennsylvania 15206 (412) 661- 7665 Laboratory Analysis Report

Lab ID No. 02-04041

E - 11

Lab# 2692

Grab

Sample Final Analysis

 Customer
 Sample Collection

 Facility Name:
 Roaring Run

 Date:
 5/27/25

 Time:
 1:12 PM

Address: 194 Tannery Rd

Champion, PA 15622

Matrix: Recreational Water Date: 5/30/25

Source Type: Pool Time: 9:00 AM
Analyst: AS

Accredited Analysis Reporting limit Results **Incubation Date/Time Analyst** Method Escherichia Coli: Absent Absent 5/28/25 9:45 AM EΒ SM 9222G Total coliforms: 9:45 AM 0/100mls 2/100mls 5/28/25 EΒ SM 9222B 5:40 PM Standard plate count: 0/ml 200/ml 5/27/25 AS SM 9215B

Field Analysis	Results	Reporting limit	Date/Time		Analyst	Method
рН:	7.6 SU	7.2 - 7.8 SU	5/27/25	1:12 PM	JC	DPD
Chlorine:	10.0 mg/l	1.0 - 5.0 mg/l	5/27/25	1:12 PM	JC	DPD
Turbidity:	1 NTU	1 - 2 NTU	5/27/25	1:12 PM	JC	Visual

Sample comments

andre Smith

Method:

(When exceeding reporting limit pool or spa is unfit)



Dream Pools and Spas 1105 Washington Blvd Pittsburgh, Pennsylvania 15206 (412) 661- 7665 Laboratory Analysis Report

Lab ID No. 02-04041

E - 11

Lab# 2692

Grab

Sample Final Analysis

 Customer
 Sample Collection

 Facility Name:
 Roaring Run

 Date:
 5/27/25

 Time:
 1:12 PM

Address: 194 Tannery Rd

Champion, PA 15622

Matrix: Recreational Water Date: 5/30/25

Source Type: Pool Time: 9:00 AM
Analyst: AS

Accredited Analysis Reporting limit Results **Incubation Date/Time Analyst** Method Escherichia Coli: Absent Absent 5/28/25 9:45 AM EΒ SM 9222G Total coliforms: 9:45 AM 0/100mls 2/100mls 5/28/25 EΒ SM 9222B 5:40 PM Standard plate count: 0/ml 200/ml 5/27/25 AS SM 9215B

Field Analysis	Results	Reporting limit	Date/Time		Analyst	Method
рН:	7.6 SU	7.2 - 7.8 SU	5/27/25	1:12 PM	JC	DPD
Chlorine:	10.0 mg/l	1.0 - 5.0 mg/l	5/27/25	1:12 PM	JC	DPD
Turbidity:	1 NTU	1 - 2 NTU	5/27/25	1:12 PM	JC	Visual

Sample comments

andre Smith

Method:

(When exceeding reporting limit pool or spa is unfit)