Dream Pools and Spas
1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661- 7665
Laboratory Analysis Report

Lab ID No. 02-04041

E - 12

Lab# **2220**

Customer
Facility Name:	*Garden City Swim Club*
Address:	*510 Garden City Dr.*
	Monroeville, PA 15146
Matrix:	*Recreational Water*
Source Type:	*Shallow End*

Sample Collection
Date:	*8/11/25*
Time:	12:45 PM
Method:	*Grab*

Sample Final Analysis
Date:	*8/14/25*
Time:	*9:00 AM*
Analyst:	*AS*

Accredited Analysis	Results	Reporting limit	Incubation Date/Time		Analyst	Method
Escherichia Coli:	Absent	Absent	8/12/25	9:00 AM	EB	SM 9222G
Total coliforms:	0/100mls	2/100mls	8/12/25	9:00 AM	EB	SM 9222B
Standard plate count:	0/ml	200/ml	8/11/25	2:31 PM	EB	SM 9215B

Field Analysis	Results	Reporting limit	Date/Time		Analyst	Method
pH:	7.6 SU	7.2 - 7.8 SU	8/11/25	12:45 PM	EH	DPD
Chlorine:	0.0 mg/l	1.0 - 5.0 mg/l	8/11/25	12:45 PM	EH	DPD
Turbidity:	1 NTU	1 - 2 NTU	8/11/25	12:45 PM	EH	Visual

Sample comments

(When exceeding reporting limit pool or spa is unfit)

Andre Smith

Andre Smith, Lead Supervisor

Customer

Facility Name:	Garden City Swim Club	
Address:	510 Garden City Dr. Monroeville, PA 15146	
Matrix:	Recreational Water	
Source Type:	Shallow End	

Sample Collection

Date:	8/11/25
Time:	12:45 PM
Method:	Grab

Sample Final Analysis

Date:	8/14/25
Time:	9:00 AM
Analyst:	AS

Accredited Analysis	Results	Reporting limit	Incubation Date/Time		Analyst	Method
Escherichia Coli:	Absent	Absent	8/12/25	9:00 AM	EB	SM 9222G
Total coliforms:	0/100mls	2/100mls	8/12/25	9:00 AM	EB	SM 9222B
Standard plate count:	0/ml	200/ml	8/11/25	2:31 PM	EB	SM 9215B

Field Analysis	Results	Reporting limit	Date/Time		Analyst	Method
pH:	7.6 SU	7.2 - 7.8 SU	8/11/25	12:45 PM	EH	DPD
Chlorine:	0.0 mg/l	1.0 - 5.0 mg/l	8/11/25	12:45 PM	EH	DPD
Turbidity:	1 NTU	1 - 2 NTU	8/11/25	12:45 PM	EH	Visual

Sample comments

(When exceeding reporting limit pool or spa is unfit)

Andre Smith

Andre Smith, Lead Supervisor