



Dream Pools and Spas
1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661-7665

Lab ID No. 02-04041

W-2

Lab# 414

Laboratory Analysis Report

<u>Customer</u>		<u>Sample Collection</u>			
Facility Name:	Town Place Airport	Date:	2/17/26		
Address:	1006 Sutherland Dr. Pittsburgh, PA 15205	Time:	12:15 PM	Method:	Grab
<u>Matrix:</u>		<u>Sample Final Analysis</u>			
Matrix:	Recreational Water	Date:	2/19/26		
Source Type:	Spa	Time:	10:30 AM	Analyst:	AS
Accredited Analysis	Results	Reporting limit	Incubation Date/Time	Analyst	Method
Escherichia Coli:	Absent	Absent	2/18/26	10:00 AM	SL SM 9222G
Total coliforms:	0/100mls	2/100mls	2/18/26	10:00 AM	SL SM 9222B
Standard plate count:	0/ml	200/ml	2/17/26	3:20 PM	SL SM 9215B
Additional Analysis	Results	Reporting limit	Incubation Date/Time	Analyst	Method
Fecal Streptococcus	0/100mls	2/100mls	2/18/26	11:00 AM	JC SM 9230C
Field Analysis	Results	Reporting limit	Date/Time	Analyst	Method
pH:	7.4 SU	7.2 - 7.8 SU	2/17/26	12:15 PM	VH DPD
Chlorine:	5.0 mg/l	1.0 - 5.0 mg/l	2/17/26	12:15 PM	VH DPD
Turbidity:	1 NTU	1 - 2 NTU	2/17/26	12:15 PM	VH Visual

Sample comments

Andre Smith, Lead Supervisor

(When exceeding reporting limit pool or spa is unfit)