



Dream Pools and Spas
1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661- 7665
Laboratory Analysis Report

Lab ID No. 02-04041
W-13

Lab# 2086

Customer

Facility Name: Centennial Point
Address: 423 Patriot Dr.
Carnegie, PA 15106

Matrix: Recreational Water
Source Type: Pool

Sample Collection

Date: 8/26/25
Time: 7:09 AM
Method: Grab

Sample Final Analysis

Date: 8/29/25
Time: 10:30 AM
Analyst: AS

Accredited Analysis	Results	Reporting limit	Incubation	Date/Time	Analyst	Method
Escherichia Coli:	Absent	Absent	8/27/25	11:00 AM	AS	SM 9222G
Total coliforms:	0/100mls	2/100mls	8/27/25	11:00 AM	AS	SM 9222B
Standard plate count:	0/ml	200/ml	8/26/25	4:55 PM	AS	SM 9215B

Field Analysis	Results	Reporting limit	Date/Time	Analyst	Method	
pH:	7.2 SU	7.2 - 7.8 SU	8/26/25	7:09 AM	AMH	DPD
Chlorine:	10.0 mg/l	1.0 - 5.0 mg/l	8/26/25	7:09 AM	AMH	DPD
Turbidity:	1 NTU	1 - 2 NTU	8/26/25	7:09 AM	AMH	Visual

Sample comments

Andre Smith, Lead Supervisor

(When exceeding reporting limit pool or spa is unfit)

Andre Smith

Andre Smith, Lead Supervisor