



Dream Pools and Spas
1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661-7665
Laboratory Analysis Report

Lab ID No. 02-04041

SERVICE

Lab# 2594

<u>Customer</u>		<u>Sample Collection</u>				
Facility Name:	Woodbridge Condo	Date:	8/25/25			
Address:	100 Club House Ln. Pittsburgh, PA 15237	Time:	9:55 AM			
Matrix:		<u>Sample Final Analysis</u>				
Source Type:	Recreational Water	Date:	8/28/25			
		Time:	9:00 AM			
		Analyst:	AS			
Accredited Analysis	Results	Reporting limit	Incubation Date/Time	Analyst	Method	
Escherichia Coli:	Absent	Absent	8/26/25	10:40 AM	AS	SM 9222G
Total coliforms:	0/100mls	2/100mls	8/26/25	10:40 AM	AS	SM 9222B
Standard plate count:	0/ml	200/ml	8/25/25	5:30 PM	AS	SM 9215B

Field Analysis	Results	Reporting limit	Date/Time	Analyst	Method	
pH:	7.6 SU	7.2 - 7.8 SU	8/25/25	9:55 AM	MM	DPD
Chlorine:	3.0 mg/l	1.0 - 5.0 mg/l	8/25/25	9:55 AM	MM	DPD
Turbidity:	1 NTU	1 - 2 NTU	8/25/25	9:55 AM	MM	Visual

Sample comments

(When exceeding reporting limit pool or spa is unfit)

Andre Smith, Lead Supervisor