



Dream Pools And Spas
1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661- 7665
Laboratory Analysis Report

Lab ID No. 02-04041

APM 1

Lab# 2084

Customer *American Pools Management*
3261 Babcock Blvd.
Pittsburgh, PA 15237

Sample Collection

Facility Name: *Castle Creek*

Date: *6/3/25*

Address: *100 Castle Creek Drive*
Seven Fields PA 16046

Time: *10:10 AM*

Method: *Grab*

Sample Final Analysis

Matrix: *Recreational Water*

Date: *6/6/25*

Source Type: *Pool*

Time: *9:30 AM*

Analyst: *AS*

Accredited Analysis	Results	Reporting limit	Incubation Date/Time	Analyst	Method
Escherichia Coli:	Absent	Absent	6/4/25	10:20 AM	AH SM 9222G
Total coliforms:	0/100mls	2/100mls	6/4/25	10:20 AM	AH SM 9222B
Standard plate count:	0/ml	200/ml	6/3/25	4:25 PM	EB SM 9215B

Field Analysis	Results	Reporting limit	Date/Time	Analyst	Method
pH:	8.0 SU	7.2 - 7.8 SU	6/3/25	10:10 AM	ZR DPD
Chlorine:	5.0 mg/l	1.0 - 5.0 mg/l	6/3/25	10:10 AM	ZR DPD
Turbidity:	1 NTU	1 - 2 NTU	6/3/25	10:10 AM	ZR Visual

Sample comments

Andre Smith

(When exceeding reporting limit pool or spa is unfit)

Andre Smith, Lead Supervisor



Dream Pools And Spas
1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661- 7665
Laboratory Analysis Report

Lab ID No. 02-04041

APM 1

Lab# 2084

Customer *American Pools Management*
3261 Babcock Blvd.
Pittsburgh, PA 15237

Sample Collection

Facility Name: *Castle Creek*

Date: *6/3/25*

Address: *100 Castle Creek Drive*
Seven Fields PA 16046

Time: *10:10 AM*

Method: *Grab*

Sample Final Analysis

Matrix: *Recreational Water*

Date: *6/6/25*

Source Type: *Pool*

Time: *9:30 AM*

Analyst: *AS*

Accredited Analysis	Results	Reporting limit	Incubation Date/Time	Analyst	Method
Escherichia Coli:	Absent	Absent	6/4/25	10:20 AM	AH SM 9222G
Total coliforms:	0/100mls	2/100mls	6/4/25	10:20 AM	AH SM 9222B
Standard plate count:	0/ml	200/ml	6/3/25	4:25 PM	EB SM 9215B

Field Analysis	Results	Reporting limit	Date/Time	Analyst	Method
pH:	8.0 SU	7.2 - 7.8 SU	6/3/25	10:10 AM	ZR DPD
Chlorine:	5.0 mg/l	1.0 - 5.0 mg/l	6/3/25	10:10 AM	ZR DPD
Turbidity:	1 NTU	1 - 2 NTU	6/3/25	10:10 AM	ZR Visual

Sample comments

Andre Smith

(When exceeding reporting limit pool or spa is unfit)

Andre Smith, Lead Supervisor