



Dream Pools and Spas
1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661- 7665
Laboratory Analysis Report

Lab ID No. 02-04041

E-1

Lab# 250

Customer

Facility Name: *Penn Towers*

Address: *1100 Penn Center Blvd.*
Pittsburgh, PA 15235

Sample Collection

Date: *10/28/25*
Time: *10:35 AM*
Method: *Grab*

Matrix: *Recreational Water*

Sample Final Analysis

Date: *10/31/25*
Time: *10:30 AM*
Analyst: *AS*

Source Type: *Pool*

Accredited Analysis	Results	Reporting limit	Incubation	Date/Time	Analyst	Method
Escherichia Coli:	Absent	Absent	10/29/25	10:00 AM	JC	SM 9222G
Total coliforms:	0/100mls	2/100mls	10/29/25	10:00 AM	JC	SM 9222B
Standard plate count:	0/ml	200/ml	10/28/25	4:00 PM	AS	SM 9215B

Field Analysis	Results	Reporting limit	Date/Time		Analyst	Method
pH:	8.2 SU	7.2 - 7.8 SU	10/28/25	10:35 AM	SH	DPD
Chlorine:	3.0 mg/l	1.0 - 5.0 mg/l	10/28/25	10:35 AM	SH	DPD
Turbidity:	1 NTU	1 - 2 NTU	10/28/25	10:35 AM	SH	Visual

Sample comments

(When exceeding reporting limit pool or spa is unfit)

Andre Smith, Lead Supervisor