



Dream Pools and Spas
1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661- 7665
Laboratory Analysis Report

Lab ID No. 02-04041

N-14

Lab# 2719

Customer

Facility Name: Meeder Flats
Address: 1000 Strand Road
Cranberry, PA 16066

Matrix: Recreational Water
Source Type: Spa

Sample Collection

Date: 7/28/25
Time: 1:20 PM
Method: Grab

Sample Final Analysis

Date: 7/31/25
Time: 9:00 AM
Analyst: AS

Accredited Analysis	Results	Reporting limit	Incubation Date/Time	Analyst	Method	
Escherichia Coli:	Absent	Absent	7/29/25	9:10 AM	EB	SM 9222G
Total coliforms:	0/100mls	2/100mls	7/29/25	9:10 AM	EB	SM 9222B
Standard plate count:	120/ml	200/ml	7/28/25	2:46 PM	EB	SM 9215B
Additional Analysis	Results	Reporting limit	Incubation Date/Time	Analyst	Method	
Fecal Streptococcus	0/100mls	2/100mls	7/29/25	11:30 AM	EB	SM 9230C

Field Analysis	Results	Reporting limit	Date/Time	Analyst	Method	
pH:	7.2 SU	7.2 - 7.8 SU	7/28/25	1:20 PM	ZR	DPD
Chlorine:	1.0 mg/l	1.0 - 5.0 mg/l	7/28/25	1:20 PM	ZR	DPD
Turbidity:	1 NTU	1 - 2 NTU	7/28/25	1:20 PM	ZR	Visual

Sample comments

Anne Smith

(When exceeding reporting limit pool or spa is unfit)



Dream Pools and Spas
1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661- 7665
Laboratory Analysis Report

Lab ID No. 02-04041

N-14

Lab# 2719

Customer

Facility Name: Meeder Flats
Address: 1000 Strand Road
Cranberry, PA 16066

Matrix: Recreational Water
Source Type: Spa

Sample Collection

Date: 7/28/25
Time: 1:20 PM
Method: Grab

Sample Final Analysis

Date: 7/31/25
Time: 9:00 AM
Analyst: AS

Accredited Analysis	Results	Reporting limit	Incubation Date/Time	Analyst	Method	
Escherichia Coli:	Absent	Absent	7/29/25	9:10 AM	EB	SM 9222G
Total coliforms:	0/100mls	2/100mls	7/29/25	9:10 AM	EB	SM 9222B
Standard plate count:	120/ml	200/ml	7/28/25	2:46 PM	EB	SM 9215B
Additional Analysis	Results	Reporting limit	Incubation Date/Time	Analyst	Method	
Fecal Streptococcus	0/100mls	2/100mls	7/29/25	11:30 AM	EB	SM 9230C

Field Analysis	Results	Reporting limit	Date/Time	Analyst	Method	
pH:	7.2 SU	7.2 - 7.8 SU	7/28/25	1:20 PM	ZR	DPD
Chlorine:	1.0 mg/l	1.0 - 5.0 mg/l	7/28/25	1:20 PM	ZR	DPD
Turbidity:	1 NTU	1 - 2 NTU	7/28/25	1:20 PM	ZR	Visual

Sample comments

Anne Smith

(When exceeding reporting limit pool or spa is unfit)