

Dream Pools and Spas 1105 Washington Blvd Pittsburgh, Pennsylvania 15206 (412) 661- 7665 Laboratory Analysis Report

Lab ID No. 02-04041 C-11

Lab# 067

<u>Customer</u>
Facility Name: Cork Factory

Address: 2349 Rail Road St. Pittsburgh, PA 15222

Matrix: Recreational Water

Source Type: Spa

Sample Collection

Date: 7/8/25
Time: 9:10 AM
Method: Grab

Sample Final Analysis

Date: 7/11/25 Time: 9:00 AM

Analyst: 9.00 AW

Accredited Analysis	Results	Reporting limit	Incubation Date/Time		Analyst	Method
Escherichia Coli:	Absent	Absent	7/9/25	9:30 AM	АН	SM 9222G
Total coliforms:	0/100mls	2/100mls	7/9/25	9:30 AM	АН	SM 9222B
Standard plate count:	570/ml	200/ml	7/8/25	4:30 PM	АН	SM 9215B
Additional Analysis	Results	Reporting limit	Incubation Date/Time		Analyst	Method
Fecal Streptococcus	0/100mls	2/100mls	7/9/25	11:00 AM	АН	SM 9230C

Field Analysis	Results	Reporting limit		Date/Time	Analyst	Method
pH:	7.2 SU	7.2 - 7.8 SU	7/8/25	9:10 AM	LM	DPD
Chlorine:	5.0 mg/l	1.0 - 5.0 mg/l	7/8/25	9:10 AM	LM	DPD
Turbidity:	1 NTU	1 - 2 NTU	7/8/25	9:10 AM	LM	Visual

Sample comments

(When exceeding reporting limit pool or spa is unfit)

Andre Smith, Lead Supervisor

andre Smith



Dream Pools and Spas 1105 Washington Blvd Pittsburgh, Pennsylvania 15206 (412) 661- 7665 Laboratory Analysis Report

Lab ID No. 02-04041 C-11

Lab# 067

<u>Customer</u>
Facility Name: Cork Factory

Address: 2349 Rail Road St. Pittsburgh, PA 15222

Matrix: Recreational Water

Source Type: Spa

Sample Collection

Date: 7/8/25
Time: 9:10 AM
Method: Grab

Sample Final Analysis

Date: 7/11/25 Time: 9:00 AM

Analyst: 9.00 AW

Accredited Analysis	Results	Reporting limit	Incubation Date/Time		Analyst	Method
Escherichia Coli:	Absent	Absent	7/9/25	9:30 AM	АН	SM 9222G
Total coliforms:	0/100mls	2/100mls	7/9/25	9:30 AM	АН	SM 9222B
Standard plate count:	570/ml	200/ml	7/8/25	4:30 PM	АН	SM 9215B
Additional Analysis	Results	Reporting limit	Incubation Date/Time		Analyst	Method
Fecal Streptococcus	0/100mls	2/100mls	7/9/25	11:00 AM	АН	SM 9230C

Field Analysis	Results	Reporting limit		Date/Time	Analyst	Method
pH:	7.2 SU	7.2 - 7.8 SU	7/8/25	9:10 AM	LM	DPD
Chlorine:	5.0 mg/l	1.0 - 5.0 mg/l	7/8/25	9:10 AM	LM	DPD
Turbidity:	1 NTU	1 - 2 NTU	7/8/25	9:10 AM	LM	Visual

Sample comments

(When exceeding reporting limit pool or spa is unfit)

Andre Smith, Lead Supervisor

andre Smith