

Dream Pools and Spas
1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661- 7665

Lab ID No. 02-04041

SERVICE

Lab# 2040

Laboratory Analysis Report

Customer

Facility Name: Berkshire Estate
Address: 6000 Middle Field Dr.
McDonald, PA 15057

Matrix: Recreational Water

Source Type: Pool

Sample Collection

Date: 8/5/25
Time: 8:12 AM
Method: Grab

Sample Final Analysis

Date: 8/8/25
Time: 8:30 AM
Analyst: AS


Accredited Analysis	Results	Reporting limit	Incubation Date/Time	Analyst	Method
Escherichia Coli:	Absent	Absent	8/6/25 11:15 AM	AH	SM 9222G
Total coliforms:	0/100mls	2/100mls	8/6/25 11:15 AM	AH	SM 9222B
Standard plate count:	0/ml	200/ml	8/5/25 5:00 PM	AS	SM 9215B

Field Analysis	Results	Reporting limit	Date/Time	Analyst	Method
pH:	7.6 SU	7.2 - 7.8 SU	8/5/25 8:12 AM	AH	DPD
Chlorine:	3.0 mg/l	1.0 - 5.0 mg/l	8/5/25 8:12 AM	AH	DPD
Turbidity:	1 NTU	1 - 2 NTU	8/5/25 8:12 AM	AH	Visual

Sample comments

(When exceeding reporting limit pool or spa is unfit)

Anaëbe Smith



Dream Pools and Spas
1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661- 7665

Lab ID No. 02-04041

SERVICE

Lab# 2040

Laboratory Analysis Report

Customer

Facility Name: Berkshire Estate
Address: 6000 Middle Field Dr.
McDonald, PA 15057

Matrix: Recreational Water

Source Type: Pool

Sample Collection

Date: 8/5/25
Time: 8:12 AM
Method: Grab

Sample Final Analysis

Date: 8/8/25
Time: 8:30 AM
Analyst: AS

Accredited Analysis	Results	Reporting limit	Incubation Date/Time	Analyst	Method
Escherichia Coli:	Absent	Absent	8/6/25 11:15 AM	AH	SM 9222G
Total coliforms:	0/100mls	2/100mls	8/6/25 11:15 AM	AH	SM 9222B
Standard plate count:	0/ml	200/ml	8/5/25 5:00 PM	AS	SM 9215B

Field Analysis	Results	Reporting limit	Date/Time	Analyst	Method
pH:	7.6 SU	7.2 - 7.8 SU	8/5/25 8:12 AM	AH	DPD
Chlorine:	3.0 mg/l	1.0 - 5.0 mg/l	8/5/25 8:12 AM	AH	DPD
Turbidity:	1 NTU	1 - 2 NTU	8/5/25 8:12 AM	AH	Visual

Sample comments

(When exceeding reporting limit pool or spa is unfit)

Anaë Smith