



**Dream Pools and Spas**  
**1105 Washington Blvd**  
**Pittsburgh, Pennsylvania 15206**  
**(412) 661- 7665**  
**Laboratory Analysis Report**

Lab ID No. 02-04041

**S-1**

**Lab# 249**

**Customer**

**Facility Name:** *Pathfinder School*  
**Address:** *50 Donati Rd.*  
*Bethel Park, PA 15102*

**Sample Collection**

**Date:** *9/30/25*  
**Time:** *2:06 PM*  
**Method:** *Grab*

**Sample Final Analysis**

**Date:** *10/3/25*  
**Time:** *11:30 AM*  
**Analyst:** *AS*

Accredited Analysis	Results	Reporting limit	Incubation Date/Time	Analyst	Method
Escherichia Coli:	Absent	Absent	10/1/25 11:00 AM	JC	SM 9222G
Total coliforms:	0/100mls	2/100mls	10/1/25 11:00 AM	JC	SM 9222B
Standard plate count:	0/ml	200/ml	9/30/25 5:00 PM	SL	SM 9215B

Field Analysis	Results	Reporting limit	Date/Time	Analyst	Method
pH:	8.0 SU	7.2 - 7.8 SU	9/30/25 2:06 PM	MM	DPD
Chlorine:	1.0 mg/l	1.0 - 5.0 mg/l	9/30/25 2:06 PM	MM	DPD
Turbidity:	1 NTU	1 - 2 NTU	9/30/25 2:06 PM	MM	Visual

**Sample comments**

( When exceeding reporting limit pool or spa is unfit)

*Andre Smith*

Andre Smith, Lead Supervisor