



**Dream Pools and Spas**  
**1105 Washington Blvd**  
**Pittsburgh, Pennsylvania 15206**  
**(412) 661- 7665**  
**Laboratory Analysis Report**

Lab ID No. 02-04041

**S-2**

**Lab# 133**

**Customer**

Facility Name: Hampton Inn - Uniontown

Address: 698 West Main Street  
Uniontown, PA 15401

Matrix: Recreational Water

Source Type: Spa

**Sample Collection**

Date: 11/10/25

Time: 1:10 PM

Method: Grab

**Sample Final Analysis**

Date: 11/13/25

Time: 10:00 AM

Analyst: AS

Accredited Analysis	Results	Reporting limit	Incubation Date/Time	Analyst	Method
---------------------	---------	-----------------	----------------------	---------	--------

Escherichia Coli:	Absent	Absent	11/11/25	9:50 AM	SL	SM 9222G
-------------------	--------	--------	----------	---------	----	----------

Total coliforms:	0/100mls	2/100mls	11/11/25	9:50 AM	SL	SM 9222B
------------------	----------	----------	----------	---------	----	----------

Standard plate count:	0/ml	200/ml	11/10/25	5:10 PM	AS	SM 9215B
-----------------------	------	--------	----------	---------	----	----------

Additional Analysis	Results	Reporting limit	Incubation Date/Time	Analyst	Method
---------------------	---------	-----------------	----------------------	---------	--------

Non-accredited

Fecal Streptococcus	0/100mls	2/100mls	11/11/25	10:30 AM	SL	SM 9230C
---------------------	----------	----------	----------	----------	----	----------

Field Analysis	Results	Reporting limit	Date/Time	Analyst	Method
----------------	---------	-----------------	-----------	---------	--------

pH:	7.2 SU	7.2 - 7.8 SU	11/10/25	1:10 PM	SH	DPD
-----	--------	--------------	----------	---------	----	-----

Chlorine:	3.0 mg/l	1.0 - 5.0 mg/l	11/10/25	1:10 PM	SH	DPD
-----------	----------	----------------	----------	---------	----	-----

Turbidity:	1 NTU	1 - 2 NTU	11/10/25	1:10 PM	SH	Visual
------------	-------	-----------	----------	---------	----	--------

**Sample comments**

Andre Smith, Lead Supervisor

( When exceeding reporting limit pool or spa is unfit)