

## **Dream Pools and Spas** 1105 Washington Blvd Pittsburgh, Pennsylvania 15206 (412) 661-7665 **Laboratory Analysis Report**

E - 10

Lab ID No. 02-04041

Lab# 2238

**Customer** Sample Collection

Facility Name: Greensburg C.C. Date: 5/29/25

Time: 1:20 PM Address: 309 Pleasant Valley Road Method: Grab

Jeannette, PA 15644

Sample Final Analysis Matrix:

Recreational Water Date: 5/31/25 Time: 3:30 PM

Source Type: Pool Analyst: AS

Accredited Analysis Results		Reporting limit	Incubation Date/Time		Analyst	Method
Escherichia Coli:	Absent	Absent	5/29/25	6:05 PM	SL	SM 9222G
Total coliforms:	0/100mls	2/100mls	5/29/25	6:05 PM	SL	SM 9222B
Standard plate count:	0/ml	200/ml	5/29/25	6:05 PM	SL	SM 9215B

Field Analysis	Results	Reporting limit	it Date/Time		Analyst	Method
pH:	7.6 SU	7.2 - 7.8 SU	5/29/25	1:20 PM	ВН	DPD
Chlorine:	7.5 mg/l	1.0 - 5.0 mg/l	5/29/25	1:20 PM	ВН	DPD
Turbidity:	1 NTU	1 - 2 NTU	5/29/25	1:20 PM	ВН	Visual

## Sample comments

( When exceeding reporting limit pool or spa is unfit)

andre Smith

Andre Smith, Lead Supervisor



## **Dream Pools and Spas** 1105 Washington Blvd Pittsburgh, Pennsylvania 15206 (412) 661-7665 **Laboratory Analysis Report**

E - 10

Lab ID No. 02-04041

Lab# 2238

**Customer** Sample Collection

Facility Name: Greensburg C.C. Date: 5/29/25

Time: 1:20 PM Address: 309 Pleasant Valley Road Method: Grab

Jeannette, PA 15644

Sample Final Analysis Matrix:

Recreational Water Date: 5/31/25 Time: 3:30 PM

Source Type: Pool Analyst: AS

Accredited Analysis Results		Reporting limit	Incubation Date/Time		Analyst	Method
Escherichia Coli:	Absent	Absent	5/29/25	6:05 PM	SL	SM 9222G
Total coliforms:	0/100mls	2/100mls	5/29/25	6:05 PM	SL	SM 9222B
Standard plate count:	0/ml	200/ml	5/29/25	6:05 PM	SL	SM 9215B

Field Analysis	Results	Reporting limit	it Date/Time		Analyst	Method
pH:	7.6 SU	7.2 - 7.8 SU	5/29/25	1:20 PM	ВН	DPD
Chlorine:	7.5 mg/l	1.0 - 5.0 mg/l	5/29/25	1:20 PM	ВН	DPD
Turbidity:	1 NTU	1 - 2 NTU	5/29/25	1:20 PM	ВН	Visual

## Sample comments

( When exceeding reporting limit pool or spa is unfit)

andre Smith

Andre Smith, Lead Supervisor