



Dream Pools and Spas
1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661- 7665
Laboratory Analysis Report

Lab ID No. 02-04041

C-10

Lab# 2554

Customer

Facility Name: Village of Shadyside

Address: 100 Denniston Ave.
Pittsburgh, Pa 15206

Matrix: Recreational Water

Source Type: Pool

Sample Collection

Date: 8/26/25

Time: 9:30 AM

Method: Grab

Sample Final Analysis

Date: 8/29/25

Time: 10:30 AM

Analyst: AS

Accredited Analysis	Results	Reporting limit	Incubation	Date/Time	Analyst	Method
Escherichia Coli:	Absent	Absent	8/27/25	12:00 PM	AS	SM 9222G
Total coliforms:	0/100mls	2/100mls	8/27/25	12:00 PM	AS	SM 9222B
Standard plate count:	0/ml	200/ml	8/26/25	6:00 PM	AS	SM 9215B

Field Analysis	Results	Reporting limit	Date/Time	Analyst	Method	
pH:	8.0 SU	7.2 - 7.8 SU	8/26/25	9:30 AM	DNP	DPD
Chlorine:	5.0 mg/l	1.0 - 5.0 mg/l	8/26/25	9:30 AM	DNP	DPD
Turbidity:	1 NTU	1 - 2 NTU	8/26/25	9:30 AM	DNP	Visual

Sample comments

(When exceeding reporting limit pool or spa is unfit)

Andre Smith, Lead Supervisor