



**Dream Pools and Spas
1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661-7665**
Laboratory Analysis Report

Lab ID No. 02-04041
C-11

Lab# 067

<u>Customer</u>		<u>Sample Collection</u>			
Facility Name:	Cork Factory	Date:	5/28/25		
Address:	2349 Rail Road St. Pittsburgh, PA 15222	Time:	9:20 AM		
Matrix:		Method:	Grab		
Source Type:		<u>Sample Final Analysis</u>			
Recreational Water		Date:	5/31/25		
Spa		Time:	9:30 AM		
		Analyst:	AS		
Accredited Analysis	Results	Reporting limit	Incubation Date/Time	Analyst	Method
Escherichia Coli:	Absent	Absent	5/29/25	10:40 AM	EB
Total coliforms:	0/100mls	2/100mls	5/29/25	10:40 AM	EB
Standard plate count:	0/ml	200/ml	5/28/25	6:25 PM	AH
Additional Analysis	Results	Reporting limit	Incubation Date/Time	Analyst	Method
Fecal Streptococcus	0/100mls	2/100mls	5/29/25	11:50 AM	AH
Field Analysis	Results	Reporting limit	Date/Time	Analyst	Method
pH:	7.6 SU	7.2 - 7.8 SU	5/28/25	9:20 AM	LM
Chlorine:	2.0 mg/l	1.0 - 5.0 mg/l	5/28/25	9:20 AM	LM
Turbidity:	1 NTU	1 - 2 NTU	5/28/25	9:20 AM	Visual

Sample comments

(When exceeding reporting limit pool or spa is unfit)

Andre Smith, Lead Supervisor



**Dream Pools and Spas
1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661-7665**
Laboratory Analysis Report

Lab ID No. 02-04041
C-11

Lab# 067

<u>Customer</u>		<u>Sample Collection</u>			
Facility Name:	Cork Factory	Date:	5/28/25		
Address:	2349 Rail Road St. Pittsburgh, PA 15222	Time:	9:20 AM		
Matrix:		Method:	Grab		
Source Type:		<u>Sample Final Analysis</u>			
Recreational Water		Date:	5/31/25		
Spa		Time:	9:30 AM		
		Analyst:	AS		
Accredited Analysis	Results	Reporting limit	Incubation Date/Time	Analyst	Method
Escherichia Coli:	Absent	Absent	5/29/25	10:40 AM	EB
Total coliforms:	0/100mls	2/100mls	5/29/25	10:40 AM	EB
Standard plate count:	0/ml	200/ml	5/28/25	6:25 PM	AH
Additional Analysis	Results	Reporting limit	Incubation Date/Time	Analyst	Method
Fecal Streptococcus	0/100mls	2/100mls	5/29/25	11:50 AM	AH
Field Analysis	Results	Reporting limit	Date/Time	Analyst	Method
pH:	7.6 SU	7.2 - 7.8 SU	5/28/25	9:20 AM	LM
Chlorine:	2.0 mg/l	1.0 - 5.0 mg/l	5/28/25	9:20 AM	LM
Turbidity:	1 NTU	1 - 2 NTU	5/28/25	9:20 AM	Visual

Sample comments

(When exceeding reporting limit pool or spa is unfit)

Andre Smith, Lead Supervisor