



Dream Pools and Spas  
1105 Washington Blvd  
Pittsburgh, Pennsylvania 15206  
(412) 661- 7665

Lab ID No. 02-04041

N-17

Laboratory Analysis Report Lab# 453

**Customer**

Facility Name: Fairfield Inn Butler

Address: 200 Fairfield Ln  
Butler, PA 16001

Matrix: Recreational Water

Source Type: Pool

**Sample Collection**

Date: 8/25/25

Time: 1:15 PM

Method: Grab

**Sample Final Analysis**

Date: 8/28/25

Time: 9:00 AM

Analyst: AS

Accredited Analysis	Results	Reporting limit	Incubation Date/Time		Analyst	Method
Escherichia Coli:	Absent	Absent	8/26/25	10:40 AM	AS	SM 9222G
Total coliforms:	0/100mls	2/100mls	8/26/25	10:40 AM	AS	SM 9222B
Standard plate count:	0/ml	200/ml	8/25/25	5:30 PM	AS	SM 9215B

Field Analysis	Results	Reporting limit	Date/Time		Analyst	Method
pH:	7.6 SU	7.2 - 7.8 SU	8/25/25	1:15 PM	BH	DPD
Chlorine:	2.0 mg/l	1.0 - 5.0 mg/l	8/25/25	1:15 PM	BH	DPD
Turbidity:	1 NTU	1 - 2 NTU	8/25/25	1:15 PM	BH	Visual

**Sample comments**

( When exceeding reporting limit pool or spa is unfit)

Andre Smith, Lead Supervisor