

## Dream Pools and Spas 1105 Washington Blvd Pittsburgh, Pennsylvania 15206 (412) 661- 7665 Laboratory Analysis Report

Lab ID No. 02-04041

APM 3

Lab# 2452

Customer American Pools Management

3261 Babcock Blvd. Pittsburgh, PA 15237

Facility Name: Rose Garden

Address: 129 Canterbury Ln.

Canonsburg, PA 15317

Matrix: Recreational Water

Source Type: Wading Pool

Sample Collection

Date: 7/22/25

Time: 10:38 AM Method: Grab

Sample Final Analysis

Date: 7/25/25 Time: 10:00 AM

Time: 10:00 AM Analyst: AS

**Accredited Analysis** Results Reporting limit **Incubation Date/Time Analyst** Method Escherichia Coli: Absent Absent 7/23/25 12:00 PM AΗ SM 9222G Total coliforms: 0/100mls 2/100mls 7/23/25 12:00 PM SM 9222B AΗ Standard plate count: 0/ml200/ml 7/22/25 6:00 PM SL SM 9215B **Additional Analysis** Results Reporting limit **Incubation Date/Time Analyst** Method 7.4 SU 7.2 - 7.8 SU AF DPD pH: 7/22/25 10:38 AM Chlorine: ΑF DPD 2.0 mg/l 1.0 - 5.0 mg/l 7/22/25 10:38 AM Turbidity: 1 NTU 1 - 2 NTU 7/22/25 10:38 AM AF Visual

## Sample comments

( When exceeding reporting limit pool or spa is unfit)

andre Smith

Andre Smith, Lead Supervisor



## Dream Pools and Spas 1105 Washington Blvd Pittsburgh, Pennsylvania 15206 (412) 661- 7665 Laboratory Analysis Report

Lab ID No. 02-04041

APM 3

Lab# 2452

Customer American Pools Management

3261 Babcock Blvd. Pittsburgh, PA 15237

Facility Name: Rose Garden

Address: 129 Canterbury Ln.

Canonsburg, PA 15317

Matrix: Recreational Water

Source Type: Wading Pool

Sample Collection

Date: 7/22/25

Time: 10:38 AM Method: Grab

Sample Final Analysis

Date: 7/25/25 Time: 10:00 AM

Time: 10:00 AM Analyst: AS

**Accredited Analysis** Results Reporting limit **Incubation Date/Time Analyst** Method Escherichia Coli: Absent Absent 7/23/25 12:00 PM AΗ SM 9222G Total coliforms: 0/100mls 2/100mls 7/23/25 12:00 PM SM 9222B AΗ Standard plate count: 0/ml200/ml 7/22/25 6:00 PM SL SM 9215B **Additional Analysis** Results Reporting limit **Incubation Date/Time Analyst** Method 7.4 SU 7.2 - 7.8 SU AF DPD pH: 7/22/25 10:38 AM Chlorine: ΑF DPD 2.0 mg/l 1.0 - 5.0 mg/l 7/22/25 10:38 AM Turbidity: 1 NTU 1 - 2 NTU 7/22/25 10:38 AM AF Visual

## Sample comments

( When exceeding reporting limit pool or spa is unfit)

andre Smith

Andre Smith, Lead Supervisor