



**Dream Pools and Spas**  
**1105 Washington Blvd**  
**Pittsburgh, Pennsylvania 15206**  
**(412) 661- 7665**  
**Laboratory Analysis Report**

Lab ID No. 02-04041

**S-10**

**Lab# 2054**

**Customer**

Facility Name: *Bower Hill Swim Club*

Address: *1600 Bower Hill Road*  
*Pittsburgh, PA 15243*

Matrix: *Recreational Water*

Source Type: *Wading Pool*

**Sample Collection**

Date: *7/7/25*

Time: *12:24 PM*

Method: *Grab*

**Sample Final Analysis**

Date: *7/10/25*

Time: *9:30 AM*

Analyst: *AS*

Accredited Analysis	Results	Reporting limit	Incubation	Date/Time	Analyst	Method
Escherichia Coli:	Absent	Absent	7/8/25	10:20 AM	AH	SM 9222G
Total coliforms:	0/100mls	2/100mls	7/8/25	10:20 AM	AH	SM 9222B
Standard plate count:	0/ml	200/ml	7/7/25	5:50 PM	EB	SM 9215B

Field Analysis	Results	Reporting limit	Date/Time	Analyst	Method	
pH:	7.6 SU	7.2 - 7.8 SU	7/7/25	12:24 PM	CW	DPD
Chlorine:	3.0 mg/l	1.0 - 5.0 mg/l	7/7/25	12:24 PM	CW	DPD
Turbidity:	1 NTU	1 - 2 NTU	7/7/25	12:24 PM	CW	Visual

**Sample comments**

( When exceeding reporting limit pool or spa is unfit)

Andre Smith, Lead Supervisor



**Dream Pools and Spas**  
**1105 Washington Blvd**  
**Pittsburgh, Pennsylvania 15206**  
**(412) 661- 7665**  
**Laboratory Analysis Report**

Lab ID No. 02-04041

**S-10**

**Lab# 2054**

**Customer**

Facility Name: *Bower Hill Swim Club*

Address: *1600 Bower Hill Road*  
*Pittsburgh, PA 15243*

Matrix: *Recreational Water*

Source Type: *Wading Pool*

**Sample Collection**

Date: *7/7/25*

Time: *12:24 PM*

Method: *Grab*

**Sample Final Analysis**

Date: *7/10/25*

Time: *9:30 AM*

Analyst: *AS*

Accredited Analysis	Results	Reporting limit	Incubation	Date/Time	Analyst	Method
Escherichia Coli:	Absent	Absent	7/8/25	10:20 AM	AH	SM 9222G
Total coliforms:	0/100mls	2/100mls	7/8/25	10:20 AM	AH	SM 9222B
Standard plate count:	0/ml	200/ml	7/7/25	5:50 PM	EB	SM 9215B

Field Analysis	Results	Reporting limit	Date/Time	Analyst	Method	
pH:	7.6 SU	7.2 - 7.8 SU	7/7/25	12:24 PM	CW	DPD
Chlorine:	3.0 mg/l	1.0 - 5.0 mg/l	7/7/25	12:24 PM	CW	DPD
Turbidity:	1 NTU	1 - 2 NTU	7/7/25	12:24 PM	CW	Visual

**Sample comments**

( When exceeding reporting limit pool or spa is unfit)

Andre Smith, Lead Supervisor