



Dream Pools and Spas
1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661- 7665
Laboratory Analysis Report

Lab ID No. 02-04041

SERVICE

Lab# 2556

Customer

Facility Name: Villas of Woodcreek
Address: 6075 Caledonia Court
Bridgeville, PA 15017

Sample Collection

Date: 8/4/25
Time: 12:59 PM
Method: Grab

Matrix: Recreational Water
Source Type: Pool

Sample Final Analysis

Date: 8/7/25
Time: 11:20 AM
Analyst: AS

Accredited Analysis	Results	Reporting limit	Incubation Date/Time	Analyst	Method
Escherichia Coli:	Absent	Absent	8/5/25 10:50 AM	AS	SM 9222G
Total coliforms:	0/100mls	2/100mls	8/5/25 10:50 AM	AS	SM 9222B
Standard plate count:	0/ml	200/ml	8/4/25 4:55 PM	AH	SM 9215B

Field Analysis	Results	Reporting limit	Date/Time	Analyst	Method
pH:	7.6 SU	7.2 - 7.8 SU	8/4/25 12:59 PM	AF	DPD
Chlorine:	5.0 mg/l	1.0 - 5.0 mg/l	8/4/25 12:59 PM	AF	DPD
Turbidity:	1 NTU	1 - 2 NTU	8/4/25 12:59 PM	AF	Visual

Sample comments

(When exceeding reporting limit pool or spa is unfit)

Andre Smith, Lead Supervisor



Dream Pools and Spas
1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661- 7665
Laboratory Analysis Report

Lab ID No. 02-04041

SERVICE

Lab# 2556

Customer

Facility Name: Villas of Woodcreek
Address: 6075 Caledonia Court
Bridgeville, PA 15017

Sample Collection

Date: 8/4/25
Time: 12:59 PM
Method: Grab

Matrix: Recreational Water
Source Type: Pool

Sample Final Analysis

Date: 8/7/25
Time: 11:20 AM
Analyst: AS

Accredited Analysis	Results	Reporting limit	Incubation Date/Time	Analyst	Method
Escherichia Coli:	Absent	Absent	8/5/25 10:50 AM	AS	SM 9222G
Total coliforms:	0/100mls	2/100mls	8/5/25 10:50 AM	AS	SM 9222B
Standard plate count:	0/ml	200/ml	8/4/25 4:55 PM	AH	SM 9215B

Field Analysis	Results	Reporting limit	Date/Time	Analyst	Method
pH:	7.6 SU	7.2 - 7.8 SU	8/4/25 12:59 PM	AF	DPD
Chlorine:	5.0 mg/l	1.0 - 5.0 mg/l	8/4/25 12:59 PM	AF	DPD
Turbidity:	1 NTU	1 - 2 NTU	8/4/25 12:59 PM	AF	Visual

Sample comments

(When exceeding reporting limit pool or spa is unfit)

Andre Smith, Lead Supervisor