

Dream Pools and Spas 1105 Washington Blvd Pittsburgh, Pennsylvania 15206 (412) 661- 7665 Laboratory Analysis Report

NIAA

N-11

Lab ID No. 02-04041

Lab# 2077

Customer

Facility Name: Camp Sky Meadow

Address: 164 Sky Meadow Lane

Avonmore, PA 15618

Matrix: Recreational Water

Source Type: Pool

Sample Collection

Date: 7/22/25

Time: 12:05 PM Method: Grab

Sample Final Analysis

 Date:
 7/25/25

 Time:
 10:00 AM

 Analyst:
 AS

Accredited Analysis Reporting limit Results **Analyst** Method **Incubation Date/Time** Escherichia Coli: Absent Absent 7/23/25 10:30 AM AΗ SM 9222G Total coliforms: 0/100mls 2/100mls 7/23/25 10:30 AM AΗ SM 9222B Standard plate count: 0/ml 200/ml 7/22/25 4:30 PM SL SM 9215B

Field Analysis	Results	Reporting limit	Date/Time		Analyst	Method
pH:	7.6 SU	7.2 - 7.8 SU	7/22/25	12:05 PM	SH	DPD
Chlorine:	1.0 mg/l	1.0 - 5.0 mg/l	7/22/25	12:05 PM	SH	DPD
Turbidity:	1 NTU	1 - 2 NTU	7/22/25	12:05 PM	SH	Visual

Sample comments

(When exceeding reporting limit pool or spa is unfit)

andre Smith

Andre Smith, Lead Supervisor



Dream Pools and Spas 1105 Washington Blvd Pittsburgh, Pennsylvania 15206 (412) 661- 7665 Laboratory Analysis Report

NIAA

N-11

Lab ID No. 02-04041

Lab# 2077

Customer

Facility Name: Camp Sky Meadow

Address: 164 Sky Meadow Lane

Avonmore, PA 15618

Matrix: Recreational Water

Source Type: Pool

Sample Collection

Date: 7/22/25

Time: 12:05 PM Method: Grab

Sample Final Analysis

 Date:
 7/25/25

 Time:
 10:00 AM

 Analyst:
 AS

Accredited Analysis Reporting limit Results **Analyst** Method **Incubation Date/Time** Escherichia Coli: Absent Absent 7/23/25 10:30 AM AΗ SM 9222G Total coliforms: 0/100mls 2/100mls 7/23/25 10:30 AM AΗ SM 9222B Standard plate count: 0/ml 200/ml 7/22/25 4:30 PM SL SM 9215B

Field Analysis	Results	Reporting limit	Date/Time		Analyst	Method
pH:	7.6 SU	7.2 - 7.8 SU	7/22/25	12:05 PM	SH	DPD
Chlorine:	1.0 mg/l	1.0 - 5.0 mg/l	7/22/25	12:05 PM	SH	DPD
Turbidity:	1 NTU	1 - 2 NTU	7/22/25	12:05 PM	SH	Visual

Sample comments

(When exceeding reporting limit pool or spa is unfit)

andre Smith

Andre Smith, Lead Supervisor