



**Dream Pools and Spas**  
**1105 Washington Blvd**  
**Pittsburgh, Pennsylvania 15206**  
**(412) 661- 7665**  
**Laboratory Analysis Report**

Lab ID No. 02-04041

**S-3**

**Lab# 200**

**Customer**

Facility Name: *L.A. Fitness Bridgeville*

Address: *1155 Washington Pike  
Bridgeville, PA 15017*

Matrix: *Recreational Water*

Source Type: *Pool*

**Sample Collection**

Date: *2/2/26*

Time: *12:12 PM*

Method: *Grab*

**Sample Final Analysis**

Date: *2/5/26*

Time: *10:30 AM*

Analyst: *AS*

Accredited Analysis	Results	Reporting limit	Incubation	Date/Time	Analyst	Method
Escherichia Coli:	Absent	Absent	2/3/26	10:00 AM	JC	SM 9222G
Total coliforms:	0/100mls	2/100mls	2/3/26	10:00 AM	JC	SM 9222B
Standard plate count:	90/ml	200/ml	2/2/26	4:10 PM	SL	SM 9215B

Field Analysis	Results	Reporting limit	Date/Time	Analyst	Method	
pH:	7.4 SU	7.2 - 7.8 SU	2/2/26	12:12 PM	GR	DPD
Chlorine:	2.0 mg/l	1.0 - 5.0 mg/l	2/2/26	12:12 PM	GR	DPD
Turbidity:	1 NTU	1 - 2 NTU	2/2/26	12:12 PM	GR	Visual

**Sample comments**

Andre Smith, Lead Supervisor

( When exceeding reporting limit pool or spa is unfit)