



Dreams Pools and Spas
1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661- 7665
Laboratory Analysis Report

Lab ID No. 02-04041

PPS

Lab# 019

Customer

Facility Name: *Baxter Building*
Address: *925 Brushton Ave*
Pittsburgh, PA 15208

Matrix: *Recreational Water*
Source Type: *Pool Shallow*

Sample Collection

Date: *12/8/25*
Time: *12:09 PM*
Method: *Grab*

Sample Final Analysis

Date: *12/11/25*
Time: *11:30 AM*
Analyst: *AS*

Accredited Analysis	Results	Rating	Incubation Date/Time		Analyst	Method
Escherichia Coli:	Absent	A	12/9/25	11:10 AM	JC	SM 9222G
Total coliforms:	0/100mls	A	12/9/25	11:10 AM	JC	SM 9222B
Standard plate count:	0/ml	A	12/8/25	5:30 PM	SL	SM 9215B

Field Analysis	Results	Rating	Date/Time		Analyst	Method
pH:	7.0 SU	E	12/8/25	12:09 PM	MM	DPD
Chlorine:	2.0 mg/l	B	12/8/25	12:09 PM	MM	DPD
Turbidity:	1 NTU	A	12/8/25	12:09 PM	MM	Visual

Sample comments

Andre Smith, Lead Supervisor

(When exceeding reporting limit pool or spa is unfit)