



Dream Pools and Spas
1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661- 7665
Laboratory Analysis Report

Lab ID No. 02-04041

C-2

Lab# 286

Customer

Facility Name: Spring Hill Suites
Address: 223 Federal St.
Pittsburgh, PA 15212

Sample Collection

Date: 9/16/25
Time: 1:40 PM
Method: Grab

Matrix: Recreational Water

Sample Final Analysis

Date: 9/19/25
Time: 9:00 AM
Analyst: AS

Source Type: Pool

Accredited Analysis	Results	Reporting limit	Incubation Date/Time		Analyst	Method
Escherichia Coli:	Absent	Absent	9/17/25	10:30 AM	JC	SM 9222G
Total coliforms:	0/100mls	2/100mls	9/17/25	10:30 AM	JC	SM 9222B
Standard plate count:	10/ml	200/ml	9/16/25	5:45 PM	AS	SM 9215B

Field Analysis	Results	Reporting limit	Date/Time		Analyst	Method
pH:	7.4 SU	7.2 - 7.8 SU	9/16/25	1:40 PM	BH	DPD
Chlorine:	3.0 mg/l	1.0 - 5.0 mg/l	9/16/25	1:40 PM	BH	DPD
Turbidity:	1 NTU	1 - 2 NTU	9/16/25	1:40 PM	BH	Visual

Sample comments

Andre Smith

(When exceeding reporting limit pool or spa is unfit)

Andre Smith, Lead Supervisor