



**Dream Pools and Spas**  
**1105 Washington Blvd**  
**Pittsburgh, Pennsylvania 15206**  
**(412) 661- 7665**  
**Laboratory Analysis Report**

Lab ID No. 02-04041

**N-17**

**Lab# 2474**

**Customer**

**Facility Name:** Sebco Park  
**Address:** 311 Hannahstown Road  
Saxonburg, PA 16023

**Sample Collection**

**Date:** 7/21/25  
**Time:** 10:35 AM  
**Method:** Grab

**Sample Final Analysis**

**Date:** 7/24/25  
**Time:** 10:00 AM  
**Analyst:** AS

**Matrix:** Recreational Water  
**Source Type:** Pool

Accredited Analysis	Results	Reporting limit	Incubation Date/Time		Analyst	Method
Escherichia Coli:	Absent	Absent	7/22/25	11:30 AM	AH	SM 9222G
Total coliforms:	0/100mls	2/100mls	7/22/25	11:30 AM	AH	SM 9222B
Standard plate count:	0/ml	200/ml	7/21/25	6:20 PM	SL	SM 9215B

Field Analysis	Results	Reporting limit	Date/Time		Analyst	Method
pH:	8.0 SU	7.2 - 7.8 SU	7/21/25	10:35 AM	BH	DPD
Chlorine:	3.0 mg/l	1.0 - 5.0 mg/l	7/21/25	10:35 AM	BH	DPD
Turbidity:	1 NTU	1 - 2 NTU	7/21/25	10:35 AM	BH	Visual

**Sample comments**

*Andre Smith*

( When exceeding reporting limit pool or spa is unfit)

Andre Smith, Lead Supervisor



**Dream Pools and Spas**  
**1105 Washington Blvd**  
**Pittsburgh, Pennsylvania 15206**  
**(412) 661- 7665**  
**Laboratory Analysis Report**

Lab ID No. 02-04041

**N-17**

**Lab# 2474**

**Customer**

Facility Name: *Sebco Park*  
Address: *311 Hannahstown Road*  
*Saxonburg, PA 16023*

**Sample Collection**

Date: *7/21/25*  
Time: *10:35 AM*  
Method: *Grab*

**Sample Final Analysis**

Date: *7/24/25*  
Time: *10:00 AM*  
Analyst: *AS*

Matrix: *Recreational Water*  
Source Type: *Pool*

Accredited Analysis	Results	Reporting limit	Incubation Date/Time		Analyst	Method
Escherichia Coli:	Absent	Absent	7/22/25	11:30 AM	AH	SM 9222G
Total coliforms:	0/100mls	2/100mls	7/22/25	11:30 AM	AH	SM 9222B
Standard plate count:	0/ml	200/ml	7/21/25	6:20 PM	SL	SM 9215B

Field Analysis	Results	Reporting limit	Date/Time		Analyst	Method
pH:	8.0 SU	7.2 - 7.8 SU	7/21/25	10:35 AM	BH	DPD
Chlorine:	3.0 mg/l	1.0 - 5.0 mg/l	7/21/25	10:35 AM	BH	DPD
Turbidity:	1 NTU	1 - 2 NTU	7/21/25	10:35 AM	BH	Visual

**Sample comments**

*Andre Smith*

( When exceeding reporting limit pool or spa is unfit)

Andre Smith, Lead Supervisor