



1105 Washington Blvd  
Pittsburgh, Pennsylvania 15206  
(412) 661- 7665  
Laboratory Analysis Report

Lab ID No. 02-04041

CP

Lab# 2444

**Customer**

Facility Name: Riverview  
Address: 400 Riverview Ave.  
Pittsburgh, PA 15214

**Sample Collection**

Date: 7/7/25  
Time: 1:30 PM  
Method: Grab

**Sample Final Analysis**

Date: 7/10/25  
Time: 9:30 AM  
Analyst: AS

Matrix: Recreational Water

Source Type: Shallow End

Accredited Analysis	Results	Reporting limit	Incubation Date/Time	Analyst	Method
Escherichia Coli:	Absent	Absent	7/8/25 9:30 AM	EB	SM 9222G
Total coliforms:	0/100mls	2/100mls	7/8/25 9:30 AM	EB	SM 9222B
Standard plate count:	0/ml	200/ml	7/7/25 3:41 PM	AH	SM 9215B

Field Analysis	Results	Reporting limit	Date/Time	Analyst	Method
pH:	7.0 SU	7.2 - 7.8 SU	7/7/25 1:30 PM	WB	DPD
Chlorine:	2.5 mg/l	1.0 - 5.0 mg/l	7/7/25 1:30 PM	WB	DPD
Turbidity:	1 NTU	1 - 2 NTU	7/7/25 1:30 PM	WB	Visual

**Sample comments**

*Andre Smith*

( When exceeding reporting limit pool or spa is unfit)

Andre Smith, Lead Supervisor



1105 Washington Blvd  
Pittsburgh, Pennsylvania 15206  
(412) 661- 7665  
Laboratory Analysis Report

Lab ID No. 02-04041

CP

Lab# 2444

**Customer**

Facility Name: Riverview  
Address: 400 Riverview Ave.  
Pittsburgh, PA 15214

**Sample Collection**

Date: 7/7/25  
Time: 1:30 PM  
Method: Grab

**Sample Final Analysis**

Date: 7/10/25  
Time: 9:30 AM  
Analyst: AS

Matrix: Recreational Water

Source Type: Shallow End

Accredited Analysis	Results	Reporting limit	Incubation Date/Time	Analyst	Method
Escherichia Coli:	Absent	Absent	7/8/25 9:30 AM	EB	SM 9222G
Total coliforms:	0/100mls	2/100mls	7/8/25 9:30 AM	EB	SM 9222B
Standard plate count:	0/ml	200/ml	7/7/25 3:41 PM	AH	SM 9215B

Field Analysis	Results	Reporting limit	Date/Time	Analyst	Method
pH:	7.0 SU	7.2 - 7.8 SU	7/7/25 1:30 PM	WB	DPD
Chlorine:	2.5 mg/l	1.0 - 5.0 mg/l	7/7/25 1:30 PM	WB	DPD
Turbidity:	1 NTU	1 - 2 NTU	7/7/25 1:30 PM	WB	Visual

**Sample comments**

*Andre Smith*

( When exceeding reporting limit pool or spa is unfit)

Andre Smith, Lead Supervisor