



**Dream Pools and Spas**  
**1105 Washington Blvd**  
**Pittsburgh, Pennsylvania 15206**  
**(412) 661- 7665**  
**Laboratory Analysis Report**

Lab ID No. 02-04041

N-11

Lab# 2069

**Customer**

Facility Name: Cambridge Manor  
Address: 100 Cambridge Drive  
Harwick , PA 15049

Matrix: Recreational Water  
Source Type: Pool

**Sample Collection**

Date: 6/17/25  
Time: 10:00 AM  
Method: Grab

**Sample Final Analysis**

Date: 6/20/25  
Time: 9:00 AM  
Analyst: AS

Accredited Analysis	Results	Reporting limit	Incubation Date/Time		Analyst	Method
Escherichia Coli:	Absent	Absent	6/18/25	10:30 AM	EB	SM 9222G
Total coliforms:	0/100mls	2/100mls	6/18/25	10:30 AM	EB	SM 9222B
Standard plate count:	0/ml	200/ml	6/17/25	5:00 PM	EB	SM 9215B

Field Analysis	Results	Reporting limit	Date/Time		Analyst	Method
pH:	7.6 SU	7.2 - 7.8 SU	6/17/25	10:00 AM	SH	DPD
Chlorine:	3.0 mg/l	1.0 - 5.0 mg/l	6/17/25	10:00 AM	SH	DPD
Turbidity:	1 NTU	1 - 2 NTU	6/17/25	10:00 AM	SH	Visual

**Sample comments**

( When exceeding reporting limit pool or spa is unfit)

Andre Smith, Lead Supervisor



**Dream Pools and Spas**  
**1105 Washington Blvd**  
**Pittsburgh, Pennsylvania 15206**  
**(412) 661- 7665**  
**Laboratory Analysis Report**

Lab ID No. 02-04041  
**N-11**

**Lab# 2069**

**Customer**

**Facility Name:** Cambridge Manor  
  
**Address:** 100 Cambridge Drive  
Harwick , PA 15049

**Matrix:** Recreational Water  
  
**Source Type:** Pool

**Sample Collection**

**Date:** 6/17/25  
**Time:** 10:00 AM  
**Method:** Grab

**Sample Final Analysis**

**Date:** 6/20/25  
**Time:** 9:00 AM  
**Analyst:** AS

Accredited Analysis	Results	Reporting limit	Incubation Date/Time		Analyst	Method
Escherichia Coli:	Absent	Absent	6/18/25	10:30 AM	EB	SM 9222G
Total coliforms:	0/100mls	2/100mls	6/18/25	10:30 AM	EB	SM 9222B
Standard plate count:	0/ml	200/ml	6/17/25	5:00 PM	EB	SM 9215B

Field Analysis	Results	Reporting limit	Date/Time		Analyst	Method
pH:	7.6 SU	7.2 - 7.8 SU	6/17/25	10:00 AM	SH	DPD
Chlorine:	3.0 mg/l	1.0 - 5.0 mg/l	6/17/25	10:00 AM	SH	DPD
Turbidity:	1 NTU	1 - 2 NTU	6/17/25	10:00 AM	SH	Visual

**Sample comments**

( When exceeding reporting limit pool or spa is unfit)

Andre Smith, Lead Supervisor