



**Dreams Pools and Spas**  
**1105 Washington Blvd**  
**Pittsburgh, Pennsylvania 15206**  
**(412) 661- 7665**  
**Laboratory Analysis Report**

Lab ID No. 02-04041

**PPS**

**Lab# 253**

**Customer**

Facility Name: Perry Traditional Academy

Address: 3875 Perrysville Ave.  
Pittsburgh, PA 15214

Matrix: Recreational Water

Source Type: Pool Shallow

**Sample Collection**

Date: 2/2/26

Time: 1:08 PM

Method: Grab

**Sample Final Analysis**

Date: 2/5/26

Time: 10:30 AM

Analyst: AS

Accredited Analysis	Results	Rating	Incubation	Date/Time	Analyst	Method
Escherichia Coli:	Absent	A	2/3/26	10:00 AM	SL	SM 9222G
Total coliforms:	0/100mls	A	2/3/26	10:00 AM	SL	SM 9222B
Standard plate count:	0/ml	A	2/2/26	4:10 PM	SL	SM 9215B

Field Analysis	Results	Rating	Date/Time	Analyst	Method	
pH:	7.6 SU	A	2/2/26	1:08 PM	MM	DPD
Chlorine:	3.5 mg/l	B	2/2/26	1:08 PM	MM	DPD
Turbidity:	1 NTU	A	2/2/26	1:08 PM	MM	Visual

**Sample comments**

Andre Smith, Lead Supervisor

( When exceeding reporting limit pool or spa is unfit)