Dream Pools and Spas
1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661- 7665
Laboratory Analysis Report

Customer		**Sample Collection**	
Facility Name:	YMCA - Schneider	*Date:*	6/24/25
		Time:	1:00 PM
Address:	2001 Ehrman Rd	*Method:*	Grab
	Cranberry, PA 16066		
		Sample Final Analysis	
Matrix:	Recreational Water	*Date:*	6/27/25
		Time:	9:20 AM
Source Type:	Large Pool	*Analyst:*	AS

Accredited Analysis	Results	Reporting limit	Incubation Date/Time		Analyst	Method
Escherichia Coli:	Absent	Absent	6/25/25	12:00 PM	EB	SM 9222G
Total coliforms:	0/100mls	2/100mls	6/25/25	12:00 PM	EB	SM 9222B
Standard plate count:	0/ml	200/ml	6/24/25	5:15 PM	AS	SM 9215B

Field Analysis	Results	Reporting limit	Date/Time		Analyst	Method
pH:	7.6 SU	7.2 - 7.8 SU	6/24/25	1:00 PM	ZR	DPD
Chlorine:	3.0 mg/l	1.0 - 5.0 mg/l	6/24/25	1:00 PM	ZR	DPD
Turbidity:	1 NTU	1 - 2 NTU	6/24/25	1:00 PM	ZR	Visual

Sample comments

(When exceeding reporting limit pool or spa is unfit)

Andre Smith

Andre Smith, Lead Supervisor

Dream Pools and Spas
1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661- 7665
Laboratory Analysis Report

Lab ID No. 02-04041

N-15

Lab# **482**

Customer

Facility Name:	YMCA - Schneider
Address:	2001 Ehrman Rd Cranberry, PA 16066
Matrix:	Recreational Water
Source Type:	Large Pool

Sample Collection

Date:	6/24/25
Time:	1:00 PM
Method:	Grab

Sample Final Analysis

Date:	6/27/25
Time:	9:20 AM
Analyst:	AS

Accredited Analysis	Results	Reporting limit	Incubation Date/Time		Analyst	Method
Escherichia Coli:	Absent	Absent	6/25/25	12:00 PM	EB	SM 9222G
Total coliforms:	0/100mls	2/100mls	6/25/25	12:00 PM	EB	SM 9222B
Standard plate count:	0/ml	200/ml	6/24/25	5:15 PM	AS	SM 9215B

Field Analysis	Results	Reporting limit	Date/Time		Analyst	Method
pH:	7.6 SU	7.2 - 7.8 SU	6/24/25	1:00 PM	ZR	DPD
Chlorine:	3.0 mg/l	1.0 - 5.0 mg/l	6/24/25	1:00 PM	ZR	DPD
Turbidity:	1 NTU	1 - 2 NTU	6/24/25	1:00 PM	ZR	Visual

Sample comments

(When exceeding reporting limit pool or spa is unfit)

Andre Smith

_____

Andre Smith, Lead Supervisor