



Dream Pools and Spas
1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661- 7665
Laboratory Analysis Report

Lab ID No. 02-04041

N-12

Lab# 2229

Customer

Facility Name: *Glen's Pool*

Address: *100 Inverness Dr.*
Pittsburgh, PA 15237

Matrix: *Recreational Water*

Source Type: *Pool*

Sample Collection

Date: *6/10/25*

Time: *1:52 PM*

Method: *Grab*

Sample Final Analysis

Date: *6/13/25*

Time: *9:30 AM*

Analyst: *AS*

| Accredited Analysis | Results | Reporting limit | Incubation Date/Time | | Analyst | Method |
|-----------------------|----------|-----------------|----------------------|----------|---------|----------|
| Escherichia Coli: | Absent | Absent | 6/11/25 | 11:30 AM | AH | SM 9222G |
| Total coliforms: | 0/100mls | 2/100mls | 6/11/25 | 11:30 AM | AH | SM 9222B |
| Standard plate count: | 0/ml | 200/ml | 6/10/25 | 5:50 PM | SL | SM 9215B |

| Field Analysis | Results | Reporting limit | Date/Time | | Analyst | Method |
|----------------|----------|-----------------|-----------|---------|---------|--------|
| pH: | 7.4 SU | 7.2 - 7.8 SU | 6/10/25 | 1:52 PM | MM | DPD |
| Chlorine: | 3.0 mg/l | 1.0 - 5.0 mg/l | 6/10/25 | 1:52 PM | MM | DPD |
| Turbidity: | 1 NTU | 1 - 2 NTU | 6/10/25 | 1:52 PM | MM | Visual |

Sample comments

(When exceeding reporting limit pool or spa is unfit)

Andre Smith, Lead Supervisor



Dream Pools and Spas
1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661- 7665
Laboratory Analysis Report

Lab ID No. 02-04041

N-12

Lab# 2229

Customer

Facility Name: Glen's Pool

Address: 100 Inverness Dr.
Pittsburgh, PA 15237

Sample Collection

Date: 6/10/25
Time: 1:52 PM
Method: Grab

Matrix: Recreational Water

Source Type: Pool

Sample Final Analysis

Date: 6/13/25
Time: 9:30 AM
Analyst: AS

| Accredited Analysis | Results | Reporting limit | Incubation Date/Time | | Analyst | Method |
|-----------------------|----------|-----------------|----------------------|----------|---------|----------|
| Escherichia Coli: | Absent | Absent | 6/11/25 | 11:30 AM | AH | SM 9222G |
| Total coliforms: | 0/100mls | 2/100mls | 6/11/25 | 11:30 AM | AH | SM 9222B |
| Standard plate count: | 0/ml | 200/ml | 6/10/25 | 5:50 PM | SL | SM 9215B |

| Field Analysis | Results | Reporting limit | Date/Time | | Analyst | Method |
|----------------|----------|-----------------|-----------|---------|---------|--------|
| pH: | 7.4 SU | 7.2 - 7.8 SU | 6/10/25 | 1:52 PM | MM | DPD |
| Chlorine: | 3.0 mg/l | 1.0 - 5.0 mg/l | 6/10/25 | 1:52 PM | MM | DPD |
| Turbidity: | 1 NTU | 1 - 2 NTU | 6/10/25 | 1:52 PM | MM | Visual |

Sample comments

(When exceeding reporting limit pool or spa is unfit)

Andre Smith, Lead Supervisor