

Dream Pools and Spas 1105 Washington Blvd Pittsburgh, Pennsylvania 15206 (412) 661-7665

Laboratory Analysis Report

W-10

Lab ID No. 02-04041

Lab# 2744

Customer

Accredited Analysis

Escherichia Coli:

Facility Name: Seven Oaks C.C.

Address: 132 Lisbon Road

Beaver, PA 15009

Matrix: Recreational Water

Results

Absent

Source Type: Adult Pool Sample Collection

Date: 7/7/25 Time: 4:14 PM Method: Grab

Sample Final Analysis

Date: 7/10/25

11:15 AM

9:30 AM Time: Analyst: AS

Incubation Date/Time Analyst Method

AΗ

SM 9222G

Total coliforms: 0/100mls 7/8/25 2/100mls 11:15 AM AΗ SM 9222B

7/8/25

Reporting limit

Absent

Standard plate count: 200/ml 7/7/25 7:00 PM AS 0/ml SM 9215B

Field Analysis	Results	Reporting limit		Date/Time	Analyst	Method	
pH:	7.2 SU	7.2 - 7.8 SU	7/7/25	4:14 PM	АН	DPD	
Chlorine:	2.0 mg/l	1.0 - 5.0 mg/l	7/7/25	4:14 PM	АН	DPD	
Turbidity:	1 NTU	1 - 2 NTU	7/7/25	4:14 PM	АН	Visual	

Sample comments

(When exceeding reporting limit pool or spa is unfit)

andre Smith

Andre Smith, Lead Supervisor



Dream Pools and Spas 1105 Washington Blvd Pittsburgh, Pennsylvania 15206 (412) 661-7665

Laboratory Analysis Report

W-10

Lab ID No. 02-04041

Lab# 2744

Customer

Accredited Analysis

Escherichia Coli:

Facility Name: Seven Oaks C.C.

Address: 132 Lisbon Road

Beaver, PA 15009

Matrix: Recreational Water

Results

Absent

Source Type: Adult Pool Sample Collection

Date: 7/7/25 Time: 4:14 PM Method: Grab

Sample Final Analysis

Date: 7/10/25

11:15 AM

9:30 AM Time: Analyst: AS

Incubation Date/Time Analyst Method

AΗ

SM 9222G

Total coliforms: 0/100mls 7/8/25 2/100mls 11:15 AM AΗ SM 9222B

7/8/25

Reporting limit

Absent

Standard plate count: 200/ml 7/7/25 7:00 PM AS 0/ml SM 9215B

Field Analysis	Results	Reporting limit		Date/Time	Analyst	Method	
pH:	7.2 SU	7.2 - 7.8 SU	7/7/25	4:14 PM	АН	DPD	
Chlorine:	2.0 mg/l	1.0 - 5.0 mg/l	7/7/25	4:14 PM	АН	DPD	
Turbidity:	1 NTU	1 - 2 NTU	7/7/25	4:14 PM	АН	Visual	

Sample comments

(When exceeding reporting limit pool or spa is unfit)

andre Smith

Andre Smith, Lead Supervisor