



**Dream Pools and Spas**  
**1105 Washington Blvd**  
**Pittsburgh, Pennsylvania 15206**  
**(412) 661- 7665**  
**Laboratory Analysis Report**

Lab ID No. 02-04041

**S-1**

**Lab# 249**

**Customer**

Facility Name: *Pathfinder School*  
Address: *50 Donati Rd.*  
*Bethel Park, PA 15102*

**Sample Collection**

Date: *10/7/25*  
Time: *2:32 PM*  
Method: *Grab*

**Sample Final Analysis**

Date: *10/10/25*  
Time: *11:30 AM*  
Analyst: *AS*

Matrix: *Recreational Water*

Source Type: *Pool*

Accredited Analysis	Results	Reporting limit	Incubation	Date/Time	Analyst	Method
Escherichia Coli:	Absent	Absent	10/8/25	11:30 AM	JC	SM 9222G
Total coliforms:	0/100mls	2/100mls	10/8/25	11:30 AM	JC	SM 9222B
Standard plate count:	0/ml	200/ml	10/7/25	5:30 PM	AS	SM 9215B

Field Analysis	Results	Reporting limit	Date/Time	Analyst	Method	
pH:	8.0 SU	7.2 - 7.8 SU	10/7/25	2:32 PM	MM	DPD
Chlorine:	3.0 mg/l	1.0 - 5.0 mg/l	10/7/25	2:32 PM	MM	DPD
Turbidity:	1 NTU	1 - 2 NTU	10/7/25	2:32 PM	MM	Visual

**Sample comments**

( When exceeding reporting limit pool or spa is unfit)

Andre Smith, Lead Supervisor