



Dream Pools and Spas
1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661- 7665
Laboratory Analysis Report

Lab ID No. 02-04041

C-1

Lab# 225

Customer

Facility Name: Metropolitan
Address: 537 N Neville St
Pittsburgh, PA 15213

Sample Collection

Date: 9/2/25
Time: 11:43 AM
Method: Grab

Matrix: Recreational Water
Source Type: Pool

Sample Final Analysis

Date: 9/5/25
Time: 10:00 AM
Analyst: AS

| Accredited Analysis | Results | Reporting limit | Incubation Date/Time | | Analyst | Method |
|-----------------------|----------|-----------------|----------------------|----------|---------|----------|
| Escherichia Coli: | Absent | Absent | 9/3/25 | 10:30 AM | SL | SM 9222G |
| Total coliforms: | 0/100mls | 2/100mls | 9/3/25 | 10:30 AM | SL | SM 9222B |
| Standard plate count: | 0/ml | 200/ml | 9/2/25 | 4:50 PM | AS | SM 9215B |

| Field Analysis | Results | Reporting limit | Date/Time | | Analyst | Method |
|----------------|----------|-----------------|-----------|----------|---------|--------|
| pH: | 7.2 SU | 7.2 - 7.8 SU | 9/2/25 | 11:43 AM | SL | DPD |
| Chlorine: | 0.0 mg/l | 1.0 - 5.0 mg/l | 9/2/25 | 11:43 AM | SL | DPD |
| Turbidity: | 1 NTU | 1 - 2 NTU | 9/2/25 | 11:43 AM | SL | Visual |

Sample comments

(When exceeding reporting limit pool or spa is unfit)

Andre Smith, Lead Supervisor