



**Dream Pools and Spas
1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661-7665
Laboratory Analysis Report**

Lab ID No. 02-04041

S-3

Lab# 075

<u>Customer</u>		<u>Sample Collection</u>				
Facility Name:	Courtyard by Marriott	Date:	1/20/26			
Address:	1800 Tanger Blvd. Washington, PA 15301	Time:	9:43 AM			
Matrix:		<u>Sample Final Analysis</u>				
Source Type:	Recreational Water	Date:	1/23/26			
	Pool	Time:	10:30 AM			
		Analyst:	AS			
Accredited Analysis	Results	Reporting limit	Incubation Date/Time	Analyst	Method	
Escherichia Coli:	Absent	Absent	1/21/26	10:00 AM	JC	SM 9222G
Total coliforms:	0/100mls	2/100mls	1/21/26	10:00 AM	JC	SM 9222B
Standard plate count:	0/ml	200/ml	1/20/26	4:27 PM	SL	SM 9215B

Field Analysis	Results	Reporting limit	Date/Time	Analyst	Method	
pH:	7.4 SU	7.2 - 7.8 SU	1/20/26	9:43 AM	GR	DPD
Chlorine:	2.0 mg/l	1.0 - 5.0 mg/l	1/20/26	9:43 AM	GR	DPD
Turbidity:	1 NTU	1 - 2 NTU	1/20/26	9:43 AM	GR	Visual

Sample comments

Andre Smith, Lead Supervisor

(When exceeding reporting limit pool or spa is unfit)