Dream Pools and Spas
1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661- 7665
Laboratory Analysis Report

Lab ID No. 02-04041

N-12

Lab# 2289

Customer	**_Sample Collection_**
Facility Name: Ingomar Swim Club	*Date:* 7/1/25
	Time: 9:22 AM
Address: 1512 Ingomar Heights Rd.	*Method:* Grab
Pittsburgh, PA 15237	
	Sample Final Analysis
Matrix: Recreational Water	*Date:* 7/4/25
	Time: 9:30 AM
Source Type: Shallow End	*Analyst:* AS

Accredited Analysis	Results	Reporting limit	Incubation Date/Time		Analyst	Method
Escherichia Coli:	Absent	Absent	7/2/25	11:05 AM	EB	SM 9222G
Total coliforms:	0/100mls	2/100mls	7/2/25	11:05 AM	EB	SM 9222B
Standard plate count:	0/ml	200/ml	7/1/25	5:37 PM	SL	SM 9215B

Field Analysis	Results	Reporting limit	Date/Time		Analyst	Method
pH:	7.6 SU	7.2 - 7.8 SU	7/1/25	9:22 AM	MM	DPD
Chlorine:	4.0 mg/l	1.0 - 5.0 mg/l	7/1/25	9:22 AM	MM	DPD
Turbidity:	1 NTU	1 - 2 NTU	7/1/25	9:22 AM	MM	Visual

Sample comments

(When exceeding reporting limit pool or spa is unfit)

Andre Smith

_____

Andre Smith, Lead Supervisor

Dream Pools and Spas
1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661- 7665
Laboratory Analysis Report

Customer			*Sample Collection*	
Facility Name:	*Ingomar Swim Club*		*Date:*	*7/1/25*
			Time:	*9:22 AM*
Address:	*1512 Ingomar Heights Rd.*		*Method:*	*Grab*
	Pittsburgh, PA 15237			
			Sample Final Analysis	
Matrix:	*Recreational Water*		*Date:*	*7/4/25*
			Time:	*9:30 AM*
Source Type:	*Shallow End*		*Analyst:*	*AS*

Accredited Analysis	Results	Reporting limit	Incubation Date/Time		Analyst	Method
Escherichia Coli:	Absent	Absent	7/2/25	11:05 AM	EB	SM 9222G
Total coliforms:	0/100mls	2/100mls	7/2/25	11:05 AM	EB	SM 9222B
Standard plate count:	0/ml	200/ml	7/1/25	5:37 PM	SL	SM 9215B

Field Analysis	Results	Reporting limit	Date/Time		Analyst	Method
pH:	7.6 SU	7.2 - 7.8 SU	7/1/25	9:22 AM	MM	DPD
Chlorine:	4.0 mg/l	1.0 - 5.0 mg/l	7/1/25	9:22 AM	MM	DPD
Turbidity:	1 NTU	1 - 2 NTU	7/1/25	9:22 AM	MM	Visual

Sample comments

(When exceeding reporting limit pool or spa is unfit)

Andre Smith

_____

Andre Smith, Lead Supervisor