

Customer

Dream Pools and Spas 1105 Washington Blvd Pittsburgh, Pennsylvania 15206 (412) 661- 7665 Laboratory Analysis Report

Lab ID No. 02-04041

W-12

Lab# 2173

Sample Collection

3:15 PM

EΒ

SM 9215B

Facility Name:	Edgeworth Clu	ub		Date:	6/4/25			
				Time:	12:45 PM			
Address:	511 East Drive	Э		Method:	Grab			
	Sewickley, PA	15143						
	-			Sample Final Analysis				
Matrix:	Recreational V	Nater		Date:	5			
				Time:	4:00 PN	1		
Source Type:	Baby Pool			Analyst:	AS	3		
	•			•				
Accredited Analysis	Results	Reporting limit	Incubation Date/Time		Analyst	Method		
Escherichia Coli:	Absent	Absent	6/4/25	3:50 PM	EB	SM 9222G		
Total coliforms:	0/100mls	2/100mls	6/4/25	3:50 PM	EB	SM 9222B		
rotar comornis.	0/10011113	2/10011113	01-1120	0.00 T W		CIVI OZZZD		

Field Analysis	Results	Reporting limit		Date/Time	Analyst	Method	_
pH:	7.4 SU	7.2 - 7.8 SU	6/4/25	12:45 PM	VH	DPD	
Chlorine:	3.0 mg/l	1.0 - 5.0 mg/l	6/4/25	12:45 PM	VH	DPD	
Turbidity:	1 NTU	1 - 2 NTU	6/4/25	12:45 PM	VH	Visual	

6/3/25

200/ml

0/ml

Sample comments

Standard plate count:

(When exceeding reporting limit pool or spa is unfit)

andre Smith

Andre Smith, Lead Supervisor



Customer

Dream Pools and Spas 1105 Washington Blvd Pittsburgh, Pennsylvania 15206 (412) 661- 7665 Laboratory Analysis Report

Lab ID No. 02-04041

W-12

Lab# 2173

Sample Collection

3:15 PM

EΒ

SM 9215B

Facility Name:	Edgeworth Clu	ub		Date:	6/4/25			
				Time:	12:45 PM			
Address:	511 East Drive	Э		Method:	Grab			
	Sewickley, PA	15143						
	-			Sample Final Analysis				
Matrix:	Recreational V	Nater		Date:	5			
				Time:	4:00 PN	1		
Source Type:	Baby Pool			Analyst:	AS	3		
	•			•				
Accredited Analysis	Results	Reporting limit	Incubation Date/Time		Analyst	Method		
Escherichia Coli:	Absent	Absent	6/4/25	3:50 PM	EB	SM 9222G		
Total coliforms:	0/100mls	2/100mls	6/4/25	3:50 PM	EB	SM 9222B		
rotar comornis.	0/10011113	2/10011113	01-1120	0.00 T W		CIVI OZZZD		

Field Analysis	Results	Reporting limit		Date/Time	Analyst	Method	_
pH:	7.4 SU	7.2 - 7.8 SU	6/4/25	12:45 PM	VH	DPD	
Chlorine:	3.0 mg/l	1.0 - 5.0 mg/l	6/4/25	12:45 PM	VH	DPD	
Turbidity:	1 NTU	1 - 2 NTU	6/4/25	12:45 PM	VH	Visual	

6/3/25

200/ml

0/ml

Sample comments

Standard plate count:

(When exceeding reporting limit pool or spa is unfit)

andre Smith

Andre Smith, Lead Supervisor