



Dream Pools and Spas
1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661- 7665
Laboratory Analysis Report

Lab ID No. 02-04041

APM 3

Lab# 2669

Customer

American Pools Management
3261 Babcock Blvd.
Pittsburgh, PA 15237

Sample Collection

Date: 6/3/25
Time: 9:27 AM
Method: Grab

Sample Final Analysis

Date: 6/6/25
Time: 9:30 AM
Analyst: AS

Facility Name: Lincoln House
Address: 245 Lincoln Ave.
Pittsburgh, PA 15202

Matrix: Recreational Water
Source Type: Pool

Accredited Analysis	Results	Reporting limit	Incubation Date/Time	Analyst	Method
Escherichia Coli:	Absent	Absent	6/4/25 11:30 AM	EB	SM 9222G
Total coliforms:	0/100mls	2/100mls	6/4/25 11:30 AM	EB	SM 9222B
Standard plate count:	0/ml	200/ml	6/3/25 5:45 PM	SL	SM 9215B

Field Analysis	Results	Reporting limit	Date/Time	Analyst	Method
pH:	7.2 SU	7.2 - 7.8 SU	6/3/25 9:27 AM	MM	DPD
Chlorine:	20.0 mg/l	1.0 - 5.0 mg/l	6/3/25 9:27 AM	MM	DPD
Turbidity:	1 NTU	1 - 2 NTU	6/3/25 9:27 AM	MM	Visual

Sample comments

Andre Smith

(When exceeding reporting limit pool or spa is unfit)

Andre Smith, Lead Supervisor



Dream Pools and Spas
1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661- 7665
Laboratory Analysis Report

Lab ID No. 02-04041

APM 3

Lab# 2669

Customer *American Pools Management*
3261 Babcock Blvd.
Pittsburgh, PA 15237

Facility Name: *Lincoln House*
Address: *245 Lincoln Ave.*
Pittsburgh, PA 15202

Sample Collection

Date: *6/3/25*
Time: *9:27 AM*
Method: *Grab*

Matrix: *Recreational Water*
Source Type: *Pool*

Sample Final Analysis

Date: *6/6/25*
Time: *9:30 AM*
Analyst: *AS*

Accredited Analysis	Results	Reporting limit	Incubation Date/Time	Analyst	Method
Escherichia Coli:	Absent	Absent	6/4/25 11:30 AM	EB	SM 9222G
Total coliforms:	0/100mls	2/100mls	6/4/25 11:30 AM	EB	SM 9222B
Standard plate count:	0/ml	200/ml	6/3/25 5:45 PM	SL	SM 9215B

Field Analysis	Results	Reporting limit	Date/Time	Analyst	Method
pH:	7.2 SU	7.2 - 7.8 SU	6/3/25 9:27 AM	MM	DPD
Chlorine:	20.0 mg/l	1.0 - 5.0 mg/l	6/3/25 9:27 AM	MM	DPD
Turbidity:	1 NTU	1 - 2 NTU	6/3/25 9:27 AM	MM	Visual

Sample comments

Andre Smith

(When exceeding reporting limit pool or spa is unfit)

Andre Smith, Lead Supervisor