



Dreams Pools and Spas
1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661- 7665
Laboratory Analysis Report

Lab ID No. 02-04041

PPS

Lab# 010

Customer

Facility Name: Arsenal Middle
Address: 3900 Butler St.
Pittsburgh, PA 15201

Matrix: Recreational Water

Source Type: Pool Shallow

Sample Collection

Date: 11/12/25
Time: 1:44 PM
Method: Grab

Sample Final Analysis

Date: 11/14/25
Time: 5:00 PM
Analyst: AS

Accredited Analysis	Results	Rating	Incubation Date/Time		Analyst	Method
Escherichia Coli:	Absent	A	11/12/25	4:45 PM	SL	SM 9222G
Total coliforms:	0/100mls	A	11/12/25	4:45 PM	SL	SM 9222B
Standard plate count:	0/ml	A	11/12/25	4:45 PM	SL	SM 9215B

Field Analysis	Results	Rating	Date/Time		Analyst	Method
pH:	7.6 SU	A	11/12/25	1:44 PM	MM	DPD
Chlorine:	3.0 mg/l	A	11/12/25	1:44 PM	MM	DPD
Turbidity:	1 NTU	A	11/12/25	1:44 PM	MM	Visual

Sample comments

Andre Smith, Lead Supervisor

(When exceeding reporting limit pool or spa is unfit)