

Dream Pools and Spas 1105 Washington Blvd Pittsburgh, Pennsylvania 15206 (412) 661- 7665 Laboratory Analysis Report

Lab ID No. 02-04041

N-14

Lab# 386

Customer

Facility Name:

Residence Inn Cranberry

Address: 1308 Freedom Rd.

Cranberry, PA 16066

Matrix:

Recreational Water

Source Type: Pool

Sample Collection

Date: 6/2/25 Time: 10:25 AM

Time: Method:

Sample Final Analysis

Date:

6/5/25 9:30 AM

Time: 9:30 AM Analyst: AS

Grab

Accredited Analysis	Results	Reporting limit	Incubation Date/Time		Analyst	Method
Escherichia Coli:	Absent	Absent	6/3/25	9:15 AM	EB	SM 9222G
Total coliforms:	0/100mls	2/100mls	6/3/25	9:15 AM	EB	SM 9222B
Standard plate count:	0/ml	200/ml	6/2/25	3:17 PM	АН	SM 9215B

Field Analysis	Results	Reporting limit	Date/Time		Analyst	Method	
pH:	8.0 SU	7.2 - 7.8 SU	6/2/25	10:25 AM	ZR	DPD	
Chlorine:	2.0 mg/l	1.0 - 5.0 mg/l	6/2/25	10:25 AM	ZR	DPD	
Turbidity:	1 NTU	1 - 2 NTU	6/2/25	10:25 AM	ZR	Visual	

Sample comments

Andre Smith, Lead Supervisor

(When exceeding reporting limit pool or spa is unfit)

andre Smith



Dream Pools and Spas 1105 Washington Blvd Pittsburgh, Pennsylvania 15206 (412) 661- 7665 Laboratory Analysis Report

Lab ID No. 02-04041

N-14

Lab# 386

Customer

Facility Name:

Residence Inn Cranberry

Address: 1308 Freedom Rd.

Cranberry, PA 16066

Matrix:

Recreational Water

Source Type: Pool

Sample Collection

Date: 6/2/25 Time: 10:25 AM

Time: Method:

Sample Final Analysis

Date:

6/5/25 9:30 AM

Time: 9:30 AM Analyst: AS

Grab

Accredited Analysis	Results	Reporting limit	Incubation Date/Time		Analyst	Method
Escherichia Coli:	Absent	Absent	6/3/25	9:15 AM	EB	SM 9222G
Total coliforms:	0/100mls	2/100mls	6/3/25	9:15 AM	EB	SM 9222B
Standard plate count:	0/ml	200/ml	6/2/25	3:17 PM	АН	SM 9215B

Field Analysis	Results	Reporting limit	Date/Time		Analyst	Method	
pH:	8.0 SU	7.2 - 7.8 SU	6/2/25	10:25 AM	ZR	DPD	
Chlorine:	2.0 mg/l	1.0 - 5.0 mg/l	6/2/25	10:25 AM	ZR	DPD	
Turbidity:	1 NTU	1 - 2 NTU	6/2/25	10:25 AM	ZR	Visual	

Sample comments

Andre Smith, Lead Supervisor

(When exceeding reporting limit pool or spa is unfit)

andre Smith