



Lab ID No. 02-04041

**Dream Pools and Spas**  
**1105 Washington Blvd**  
**Pittsburgh, Pennsylvania 15206**  
**(412) 661- 7665**  
**Laboratory Analysis Report**

Service

Lab# 313

**Customer**

Facility Name: UPMC Sports Rehab - Cranberry

Address: 8000 Cranberry Springs Drive  
Cranberry Township, PA 16066

Matrix: Recreational Water

Source Type: Spa

**Sample Collection**

Date: 12/30/25

Time: 10:30 AM

Method: Grab

**Sample Final Analysis**

Date: 1/2/26

Time: 10:30 AM

Analyst: AS

Accredited Analysis	Results	Reporting limit	Incubation Date/Time		Analyst	Method
Escherichia Coli:	Absent	Absent	12/31/25	10:00 AM	SL	SM 9222G
Total coliforms:	0/100mls	2/100mls	12/31/25	10:00 AM	SL	SM 9222B
Standard plate count:	0/ml	200/ml	12/30/25	4:54 PM	SL	SM 9215B

Additional Analysis	Results	Reporting limit	Incubation Date/Time		Analyst	Method
Fecal Streptococcus	0/100mls	2/100mls	12/31/25	10:10 AM	SL	SM 9230C

Field Analysis	Results	Reporting limit	Date/Time		Analyst	Method
pH:	7.4 SU	7.2 - 7.8 SU	12/30/25	10:30 AM	JR	DPD
Chlorine:	1.5 mg/l	1.0 - 5.0 mg/l	12/30/25	10:30 AM	JR	DPD
Turbidity:	1 NTU	1 - 2 NTU	12/30/25	10:30 AM	JR	Visual

**Sample comments**

Andre Smith, Lead Supervisor

( When exceeding reporting limit pool or spa is unfit)