



Dream Pools and Spas
1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661- 7665
Laboratory Analysis Report

Lab ID No. 02-04041
N-2

Lab# 120

Customer

Facility Name: Wingate

Address: 210 Executive Dr.
Cranberry, PA 16066

Matrix: Recreational Water

Source Type: Spa

Sample Collection

Date: 9/3/25
Time: 12:15 PM
Method: Grab

Sample Final Analysis

Date: 9/6/25
Time: 2:00 PM
Analyst: AS

Accredited Analysis	Results	Reporting limit	Incubation Date/Time	Analyst	Method
---------------------	---------	-----------------	----------------------	---------	--------

Escherichia Coli:	Absent	Absent	9/4/25 9:15 AM	JC	SM 9222G
Total coliforms:	0/100mls	2/100mls	9/4/25 9:15 AM	JC	SM 9222B
Standard plate count:	0/ml	200/ml	9/3/25 3:10 PM	SL	SM 9215B

Additional Analysis	Results	Reporting limit	Incubation Date/Time	Analyst	Method
---------------------	---------	-----------------	----------------------	---------	--------

Fecal Streptococcus	0/100mls	2/100mls	9/4/25 10:40 AM	AS	SM 9230C
---------------------	----------	----------	-----------------	----	----------

Field Analysis	Results	Reporting limit	Date/Time	Analyst	Method
----------------	---------	-----------------	-----------	---------	--------

pH:	7.4 SU	7.2 - 7.8 SU	9/3/25 12:15 PM	VH	DPD
Chlorine:	5.0 mg/l	1.0 - 5.0 mg/l	9/3/25 12:15 PM	VH	DPD
Turbidity:	1 NTU	1 - 2 NTU	9/3/25 12:15 PM	VH	Visual

Sample comments

Andre Smith

(When exceeding reporting limit pool or spa is unfit)

Andre Smith, Lead Supervisor