



Dream Pools and Spas
1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661- 7665
Laboratory Analysis Report

Lab ID No. 02-04041

W-12

Lab# 364

Customer

Facility Name: YMCA - Sewickley
Address: 625 Blackburn Road
Sewickley, PA 15143

Matrix: Recreational Water

Source Type: Small Pool

Sample Collection

Date: 7/23/25
Time: 12:30 PM
Method: Grab

Sample Final Analysis


Date: 7/25/25
Time: 2:00 PM
Analyst: AS

Accredited Analysis	Results	Reporting limit	Incubation Date/Time	Analyst	Method
Escherichia Coli:	Absent	Absent	7/23/25 4:27 PM	SL	SM 9222G
Total coliforms:	0/100mls	2/100mls	7/23/25 4:27 PM	SL	SM 9222B
Standard plate count:	0/ml	200/ml	7/23/25 4:27 PM	SL	SM 9215B

Field Analysis	Results	Reporting limit	Date/Time	Analyst	Method
pH:	7.2 SU	7.2 - 7.8 SU	7/23/25 12:30 PM	VH	DPD
Chlorine:	3.0 mg/l	1.0 - 5.0 mg/l	7/23/25 12:30 PM	VH	DPD
Turbidity:	1 NTU	1 - 2 NTU	7/23/25 12:30 PM	VH	Visual

Sample comments

(When exceeding reporting limit pool or spa is unfit)


Andrea Smith, Lead Supervisor



Dream Pools and Spas
1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661- 7665
Laboratory Analysis Report

Lab ID No. 02-04041

W-12

Lab# 364

Customer

Facility Name: YMCA - Sewickley
Address: 625 Blackburn Road
Sewickley, PA 15143

Matrix: Recreational Water

Source Type: Small Pool

Sample Collection

Date: 7/23/25
Time: 12:30 PM
Method: Grab

Sample Final Analysis


Date: 7/25/25
Time: 2:00 PM
Analyst: AS

Accredited Analysis	Results	Reporting limit	Incubation Date/Time		Analyst	Method
Escherichia Coli:	Absent	Absent	7/23/25	4:27 PM	SL	SM 9222G
Total coliforms:	0/100mls	2/100mls	7/23/25	4:27 PM	SL	SM 9222B
Standard plate count:	0/ml	200/ml	7/23/25	4:27 PM	SL	SM 9215B

Field Analysis	Results	Reporting limit	Date/Time		Analyst	Method
pH:	7.2 SU	7.2 - 7.8 SU	7/23/25	12:30 PM	VH	DPD
Chlorine:	3.0 mg/l	1.0 - 5.0 mg/l	7/23/25	12:30 PM	VH	DPD
Turbidity:	1 NTU	1 - 2 NTU	7/23/25	12:30 PM	VH	Visual

Sample comments

(When exceeding reporting limit pool or spa is unfit)


Andrew Smith, Lead Supervisor