



Dream Pools and Spas
1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661- 7665
Laboratory Analysis Report

Lab ID No. 02-04041

C-2

Lab# 090

Customer

Facility Name: Doubletree Hotel
Address: Bigelow Square
Pittsburgh, PA 15219

Sample Collection

Date: 10/14/25
Time: 11:20 AM
Method: Grab

Sample Final Analysis

Date: 10/17/25
Time: 11:00 AM
Analyst: AS

| Accredited Analysis | Results | Reporting limit | Incubation Date/Time | Analyst | Method |
|-----------------------|----------|-----------------|----------------------|---------|----------|
| Escherichia Coli: | Absent | Absent | 10/15/25 10:30 AM | JC | SM 9222G |
| Total coliforms: | 0/100mls | 2/100mls | 10/15/25 10:30 AM | JC | SM 9222B |
| Standard plate count: | 0/ml | 200/ml | 10/14/25 5:10 PM | SL | SM 9215B |

| Field Analysis | Results | Reporting limit | Date/Time | Analyst | Method |
|----------------|----------|-----------------|-------------------|---------|--------|
| pH: | 7.4 SU | 7.2 - 7.8 SU | 10/14/25 11:20 AM | BH | DPD |
| Chlorine: | 2.0 mg/l | 1.0 - 5.0 mg/l | 10/14/25 11:20 AM | BH | DPD |
| Turbidity: | 1 NTU | 1 - 2 NTU | 10/14/25 11:20 AM | BH | Visual |

Sample comments

(When exceeding reporting limit pool or spa is unfit)

Andre Smith, Lead Supervisor